

City of Broken Arrow WTP Monthly Operational Report Summary
Water Treatment Plant PWSID# OK 1021508

Reporting Period: [April] [2025]



**CITY OF
BROKEN ARROW**
Where opportunity lives

Operating Data Summary

Water Production (MG)

	Month	Average Day
Raw Water Treated	330.83	11.0
Finished Water	321.42	10.7

Monthly Chemical Usage (Non-Membrane Usage)

Chemical	Total lbs	lbs/Finished MG
Sodium Hypochlorite	23,825	1,058.9
Salt (for hypo generation)	71,475	3,176.8
Liquid Ammonium Sulfate	3,051	9.1
Sodium Permanganate	1,949	3.1
Aluminum Chlorohydrate	85,791	47.8
Sodium Hydroxide	11,030	13.2
Hydrofluosilicic Acid	852	1.5

Total Chlorine Residual:

	No. Samples
Total Chlorine Residual <2.0 mg/L Leaving Plant	0

Finished Water Turbidity:

	No. Samples	% of Total Samples
Greater than 0.5 NTU	0	0.00
Greater than 0.3 NTU	0	0.00
Greater than 0.1 NTU	0	0.00
Total No. of Turbidity Samples	180	
Highest Turbidity Reading	0.083	
No. Samples > 1 NTU	0	
No. Samples > 5 NTU	0	

Monthly Costs

	Total	\$/Finished MG	\$/1000 gal
Plant Electricity	\$48,491.63	\$150.87	\$0.1509
Total Chemical	\$104,652.37	\$325.59	\$0.3256
Total Labor	\$115,229.52	\$358.50	\$0.3585
Services	\$32,643.67	\$101.56	\$0.1016
Materials and Supplies	\$8,428.55	\$26.22	\$0.0262
Equipment Expenses	\$15,449.37	\$48.07	\$0.0481
Total	\$324,895.11	\$1,010.81	\$1.0108

Individual Membrane Unit Turbidity Checklist

	YES/NO
1. IS TURBIDITY FROM EACH INDIVIDUAL MEMBRANE UNIT RECORDED EVERY 15 MINUTES?	YES
2. DID ANY SINGLE MEMBRANE UNIT EXCEED 2.0 NTU IN TWO CONSECUTIVE 15 MINUTE PERIODS?	NO
No, Go to Question 3.	
Yes, What date was the membrane profile completed?	
DID THIS SAME MEMBRANE UNIT EXCEED 2.0 NTU IN 2 CONSECUTIVE 15-MIN PERIODS DURING THE LAST MONTH?	
No, Go to Question 3.	
Yes, Schedule Comprehensive Performance Evaluation (CPE) with DEQ.	
3. DID ANY SINGLE MEMBRANE UNIT EXCEED 1.0 NTU IN TWO CONSECUTIVE 15 MINUTE PERIODS?	NO
No, Go to Question 4.	
Yes, What date was the filter profile completed?	
DID THIS SAME MEMBRANE UNIT FILTER EXCEED 1.0 NTU IN 2 CONSECUTIVE 15-MIN PERIODS DURING THE LAST 2 MONTHS?	
No, Go to Question 4.	
Yes, What date was the membrane self-assessment completed?	
4. DID ANY SINGLE MEMBRANE UNIT EXCEED 0.5 NTU IN 2 CONSECUTIVE 15-MIN PERIODS AT THE END OF 4 HRS OF OPERATION?	NO
No, You are finished with the checklist.	
Yes, What date was the membrane profile completed?	

*** IF ANY OF QUESTIONS 2 THROUGH 4 ARE CHECKED "YES", YOU MUST COMPLETE THE TURBIDITY TRIGGER EVALUATION FORM AND ATTACH TO THIS MOR.**

I hereby certify the above to be correct to the best of my knowledge:

Notes: Fluoride feed shut down starting the 23rd for repairs.

Signed:

LouAnn Fisher

5/9/2025

Date

Title:

Water Plant Manager

Operator Certificate No.

25369

Public Water System Name: COBA Water Treatment Plant
PWS ID No.: OK 1021508

Month:
Year

April
2025

Date	Water Production and Recycle Flows				
	Raw Water Pumped to Pre-Sed Basins (MG)	Raw Water Treated (MG)	Finished Water Delivered (MG)	Reverse Filtration Water Used (MG)	Lagoon Decant Water Pumped (MG)
1	27.59	10.86	10.14		0.58
2	8.93	10.50	10.16		0.59
3	0.00	10.08	9.76		0.60
4	0.00	9.56	9.26		0.66
5	0.00	9.68	9.11		0.98
6	0.00	9.49	9.93		0.59
7	5.61	11.35	10.98		0.55
8	20.42	12.49	12.13		0.54
9	20.36	11.78	11.72		0.55
10	20.30	11.20	10.91		0.56
11	20.13	11.26	11.40		0.68
12	19.99	11.59	11.41		0.84
13	19.91	13.29	12.77		0.54
14	10.57	14.20	14.37		0.55
15	16.19	12.71	11.84		0.59
16	12.10	12.67	12.27		0.72
17	10.19	12.66	12.01		0.91
18	16.25	12.89	11.67		0.66
19	0.00	10.69	10.01		0.70
20	0.00	9.13	9.10		1.01
21	0.00	10.65	10.49		0.72
22	0.00	10.44	10.16		0.64
23	0.00	10.64	10.65		0.63
24	0.00	10.70	10.72		0.60
25	15.62	10.28	10.69		0.42
26	21.25	11.09	9.88		0.44
27	21.08	9.46	9.07		0.46
28	20.80	10.61	10.61		0.68
29	20.68	9.90	9.15		0.71
30	5.10	8.97	9.07		0.91
31					
TOTAL	333.08	330.83	321.42	0.00	19.62
AVG	11.10	11.03	10.71	#DIV/0!	0.65
MAX	27.59	14.20	14.37	0.00	1.01
MIN	0.00	8.97	9.07	0.00	0.42

Public Water System Name: COBA Water Treatment Plant
PWS ID No.: OK 1021508

Month: April
Year: 2025

TOTAL CHEMICAL COST:		\$104,652	
Cost Per MG Treated	\$316.34	Cost Per MG Delivered	\$325.59
Million Gallons Treated	330.83	Million Gallons Delivered	321.42

Non-Membrane System Chemical Usage

Date	Sodium Hypochlorite (CL) NaClO		Liquid Ammonium Sulfate (LAS)		Sodium Permanganate (SP)		Aluminum Chlorohydrate (ACH)		Sodium Hydroxide (SH)		Hydrofluosilicic Acid (HFS)	
	gal/day	lb/day	gal/day	lb/day	gal/day	lb/day	gal/day	lb/day	gal/day	lb/day	gal/day	lb/day
1	8,341	583.88	89.6	93.87	62.6	121.13	493	2757.49	100.2	261.19	19.5	35.43
2	8,191	573.35	87.6	91.79	20.9	40.47	484	2704.45	98.0	255.46	19.0	34.65
3	7,896	552.75	84.1	88.12	0.0	0.00	466	2604.66	94.2	245.47	18.3	33.26
4	8,197	573.78	79.9	83.71	0.0	0.00	443	2473.27	89.7	233.70	17.3	31.60
5	8,843	619.00	79.2	83.05	0.0	0.00	438	2450.19	89.0	232.00	17.2	31.35
6	9,667	676.72	86.5	90.61	0.0	0.00	476	2657.65	98.6	256.85	18.7	34.10
7	10,628	743.99	96.9	101.51	14.7	28.44	532	2969.98	117.7	306.70	20.8	37.96
8	11,527	806.88	105.6	110.68	55.6	107.58	582	3252.04	136.1	354.60	22.7	41.39
9	10,941	765.88	98.1	102.85	58.2	112.69	539	3012.93	132.8	346.17	21.1	38.46
10	11,461	802.26	97.8	102.53	64.5	124.75	537	2999.23	140.4	365.90	21.1	38.34
11	12,039	842.76	98.9	103.61	63.9	123.71	544	3037.42	141.8	369.57	21.3	38.75
12	12,390	867.30	99.4	104.15	63.5	122.89	542	3029.45	142.6	371.52	21.4	38.95
13	14,069	984.85	111.7	117.10	63.2	122.32	615	3435.18	174.3	454.26	24.0	43.79
14	15,467	1082.70	125.5	131.48	33.9	65.60	681	3807.95	211.6	551.50	26.6	48.36
15	13,398	937.83	114.0	119.51	51.1	98.81	593	3313.71	190.6	496.88	23.3	42.45
16	12,884	901.88	114.5	120.00	38.8	75.05	576	3218.16	186.0	484.72	22.7	41.39
17	13,039	912.76	117.0	122.61	32.0	61.94	588	3283.41	188.7	491.82	23.1	42.00
18	12,649	885.43	113.5	119.00	52.2	101.09	570	3185.67	183.2	477.46	22.4	40.76
19	10,786	755.01	95.0	99.61	0.0	0.08	472	2637.04	153.7	400.67	18.7	34.12
20	9,882	691.77	85.4	89.49	0.0	0.00	423	2363.01	139.3	363.11	17.0	30.88
21	11,423	799.58	98.3	103.03	0.0	0.00	502	2802.32	161.6	421.18	19.7	35.89
22	11,142	779.91	95.6	100.24	0.0	0.00	484	2704.96	157.2	409.67	19.2	34.92
23	11,743	821.98	99.5	104.30	0.0	0.00	506	2825.17	163.5	426.16	12.8	23.35
24	12,224	855.68	100.8	105.64	0.0	0.00	512	2861.75	165.5	431.46	0.0	0.00
25	12,438	870.64	97.6	102.31	48.9	94.64	495	2763.28	160.2	417.53	0.0	0.00
26	12,173	852.12	93.9	98.43	67.5	130.64	477	2663.96	133.7	348.36	0.0	0.00
27	11,207	784.46	83.4	87.45	67.0	129.56	423	2365.82	115.4	300.79	0.0	0.00
28	13,661	956.26	101.9	106.75	66.1	127.83	528	2951.87	142.0	370.14	0.0	0.00
29	11,216	785.09	81.8	85.70	65.7	127.11	434	2422.79	114.4	298.24	0.0	0.01
30	10,838	758.65	78.5	82.26	16.9	32.65	400	2236.30	109.9	286.49	0.0	0.00
31												
TOTAL	340,359	23,825	2,912	3,051	1,007	1,949	15,353	85,791	4,232	11,030	468	852
AVG	11,345	794.17	97	101.71	34	64.97	512	2859.70	141	367.65	16	28.41
MAX	15,467	1082.70	125	131.48	68	130.64	681	3807.95	212	551.50	27	48.36
MIN	7,896	552.75	78	82.26	0	0.00	400	2236.30	89	232.00	0	0.00
COST	\$13,101.81		\$5,273.30		\$14,383.42		\$60,053.78		\$9,264.84		\$2,575.23	
\$/MG	\$39.60		\$15.94		\$43.48		\$181.53		\$28.01		\$7.78	

Public Water System Name: COBA Water Treatment Plant
PWS ID No.: OK 1021508

Month: April
Year: 2025

Date	pH (by Continuous Reading Analyzers)				Hardness and Alkalinity - Finished Water Grab Samples						
	Membrane Filtrate		Finished Water		Hardness (ppm)		Alkalinity (ppm as CaCO ₃)				CaCO ₃ Stability
							Phenol	Phenol	Total	Total	
	Daily Max	Daily Min	Daily Max	Daily Min	AM	PM	AM	PM	AM	PM	
1	7.9	7.9	8.2	8.2	197.00	204.00	0.00	0.00	114.00	117.00	6.00
2	7.9	7.8	8.2	8.1	206.00	203.00	0.00	0.00	117.00	117.00	6.00
3	7.8	7.8	8.2	8.1	206.00	201.00	0.00	0.00	116.00	117.00	5.00
4	7.8	7.8	8.1	8.1	203.00	203.00	0.00	0.00	115.00	118.00	7.00
5	7.8	7.8	8.1	8.0	201.00	200.00	0.00	0.00	115.00	117.00	2.00
6	7.8	7.8	8.0	8.0	200.00	200.00	0.00	0.00	117.00	113.00	2.00
7	7.8	7.8	8.1	8.0	198.00	204.00	0.00	0.00	114.00	120.00	0.00
8	7.8	7.8	8.1	8.1	212.00	201.00	0.00	0.00	121.00	117.00	7.00
9	7.8	7.7	8.1	8.1	200.00	205.00	0.00	0.00	115.00	116.00	4.00
10	7.8	7.7	8.1	8.1	211.00	191.00	0.00	0.00	125.00	106.00	8.00
11	7.8	7.7	8.1	8.1	199.00	198.00	0.00	0.00	117.00	114.00	8.00
12	7.7	7.7	8.1	8.0	192.00	197.00	0.00	0.00	112.00	113.00	6.00
13	7.7	7.7	8.1	8.0	192.00	189.00	0.00	0.00	112.00	112.00	6.00
14	7.8	7.7	8.3	8.1	187.00	191.00	0.00	0.00	111.00	112.00	4.00
15	7.7	7.7	8.3	8.2	189.00	191.00	0.00	0.00	112.00	116.00	7.00
16	7.7	7.5	8.3	8.2	192.00	185.00	0.00	0.00	110.00	114.00	6.00
17	7.7	7.6	8.2	8.2	186.00	182.00	0.00	0.00	112.00	115.00	8.00
18	7.7	7.4	8.3	8.2	181.00	182.00	0.00	0.00	110.00	110.00	1.00
19	7.8	7.6	8.3	8.2	184.00	181.00	0.00	0.00	112.00	110.00	5.00
20	7.7	7.7	8.3	8.2	192.00	180.00	0.00	0.00	110.00	111.00	7.00
21	7.7	7.7	8.3	8.2	181.00	174.00	0.00	0.00	110.00	107.00	6.00
22	7.7	7.7	8.3	8.2	175.00	171.00	0.00	0.00	106.00	112.00	7.00
23	7.7	7.7	8.3	8.2	177.00	174.00	0.00	0.00	111.00	108.00	9.00
24	7.7	7.7	8.3	8.3	173.00	178.00	0.00	0.00	108.00	109.00	5.00
25	7.7	7.6	8.4	8.3	172.00	176.00	0.00	0.00	109.00	110.00	8.00
26	7.7	7.6	8.3	8.2	181.00	176.00	0.00	0.00	109.00	109.00	3.00
27	7.6	7.6	8.2	8.1	183.00	170.00	0.00	0.00	110.00	108.00	1.00
28	7.6	7.6	8.1	8.1	170.00	167.00	0.00	0.00	113.00	107.00	5.00
29	7.7	7.6	8.2	8.1	168.00	168.00	0.00	0.00	106.00	107.00	5.00
30	8.2	7.6	8.2	8.2	174.00	172.00	0.00	0.00	107.00	107.00	2.00
31											
AVG					189	187	0	0	113	112	5
MAX	8.2	7.9	8.4	8.3	212	205	0	0	125	120	9
MIN	7.6	7.4	8.0	8.0	168	167	0	0	106	106	0

Date	Turbidity (NTU) Continuous Reading Analyzers						Chlorine Residual (Total or Free as Noted, mg/L) Continuous Reading Analyzers					
	Finished Water (Highest Reading in 4-hour Period)						Finished Water Total Chlorine (Min. in 4 Hour Period)					
	12:00 AM	4:00 AM	8:00 AM	12:00 PM	4:00 PM	8:00 PM	12:00 AM	4:00 AM	8:00 AM	12:00 PM	4:00 PM	8:00 PM
1	0.02	0.02	0.02	0.02	0.02	0.02	3.37	3.49	3.46	3.45	3.42	3.41
2	0.02	0.02	0.02	0.02	0.02	0.02	3.25	3.36	3.35	3.31	3.28	3.26
3	0.02	0.02	0.02	0.02	0.02	0.02	3.08	3.28	3.31	3.24	3.18	3.12
4	0.02	0.02	0.02	0.02	0.02	0.02	3.10	3.04	2.99	2.98	3.00	3.06
5	0.02	0.02	0.02	0.02	0.02	0.02	3.22	3.16	3.22	3.24	3.23	3.22
6	0.02	0.02	0.02	0.02	0.02	0.02	3.24	3.24	3.27	3.29	3.27	3.23
7	0.02	0.02	0.02	0.02	0.02	0.02	3.33	3.26	3.28	3.30	3.31	3.33
8	0.02	0.02	0.02	0.02	0.02	0.02	3.32	3.40	3.43	3.40	3.34	3.32
9	0.02	0.02	0.02	0.02	0.02	0.02	3.23	3.27	3.26	3.24	3.24	3.23
10	0.02	0.02	0.02	0.02	0.02	0.02	3.19	3.24	3.28	3.27	3.20	3.20
11	0.02	0.02	0.02	0.02	0.02	0.02	3.26	3.28	3.29	3.27	3.26	3.23
12	0.02	0.02	0.02	0.02	0.02	0.02	3.29	3.24	3.24	3.24	3.24	3.24
13	0.02	0.02	0.02	0.02	0.02	0.02	3.42	3.32	3.36	3.41	3.40	3.29
14	0.02	0.02	0.02	0.02	0.02	0.02	3.50	3.45	3.58	3.61	3.58	3.48
15	0.02	0.02	0.02	0.02	0.02	0.02	3.60	3.53	3.55	3.58	3.60	3.59
16	0.02	0.02	0.02	0.02	0.02	0.02	3.64	3.61	3.60	3.60	3.62	3.61
17	0.02	0.02	0.02	0.02	0.02	0.02	3.58	3.65	3.65	3.64	3.63	3.59
18	0.02	0.02	0.03	0.02	0.02	0.02	3.56	3.53	3.65	3.66	3.64	3.61
19	0.02	0.03	0.02	0.02	0.02	0.02	3.43	3.53	3.49	3.47	3.46	3.45
20	0.02	0.02	0.02	0.02	0.02	0.02	3.34	3.42	3.39	3.36	3.33	3.32
21	0.02	0.03	0.02	0.02	0.02	0.02	3.40	3.34	3.35	3.37	3.37	3.40
22	0.02	0.02	0.02	0.02	0.02	0.02	3.30	3.38	3.38	3.34	3.31	3.29
23	0.02	0.02	0.04	0.02	0.02	0.02	3.31	3.33	3.32	3.29	3.26	3.25
24	0.02	0.02	0.03	0.02	0.02	0.02	3.33	3.43	3.41	3.39	3.37	3.34
25	0.02	0.02	0.02	0.02	0.02	0.02	3.46	3.33	3.37	3.39	3.37	3.38
26	0.02	0.05	0.02	0.04	0.03	0.02	3.38	3.48	3.45	3.43	3.41	3.38
27	0.03	0.03	0.03	0.02	0.02	0.05	3.35	3.38	3.32	3.32	3.32	3.32
28	0.03	0.05	0.06	0.03	0.02	0.08	3.39	3.37	3.47	3.46	3.46	3.39
29	0.03	0.03	0.08	0.05	0.03	0.04	3.29	3.36	3.40	3.21	2.99	3.24
30	0.02	0.03	0.03	0.03	0.05	0.04	3.44	3.35	3.38	3.41	3.42	3.43
31												
AVG	0.02	0.02	0.02	0.02	0.02	0.02	3.4	3.4	3.4	3.4	3.4	3.3
MAX	0.03	0.05	0.08	0.05	0.05	0.08	3.6	3.6	3.7	3.7	3.6	3.6
MIN	0.02	0.02	0.02	0.02	0.02	0.02	3.1	3.0	3.0	3.0	3.0	3.1

Finished Water Turbidity Summary and Statistics

	No. of Samples	Percent of Total Samples
Turbidity Greater Than 0.5 NTU	0	0
Turbidity Greater Than 0.3 NTU	0	0
Turbidity Greater Than 0.1 NTU	0	0

Total Number of Turbidity Samples	180
-----------------------------------	-----

PWSID 1021508

SYSTEM

COBA WTP

MONTH April

*Type of Material Applied

Hydrofluosilicic Acid

YEAR 2025

Date	Water Treated 1,000s of Gallons	APPLIED		RESIDUAL F, ppm (RAW)		RESIDUAL F, ppm (FINISHED WATER)	
		LBS/DAY	PPM of F	AM	PM	AM	PM
1	10,140	35	0.42	0.41	0.32	0.86	0.72
2	10,157	35	0.41	0.40	0.29	0.82	0.74
3	9,758	33	0.41	0.38	0.27	0.83	0.76
4	9,261	32	0.41	0.36	0.41	0.72	0.82
5	9,108	31	0.41	0.36	0.45	0.66	0.97
6	9,927	34	0.41	0.44	0.45	0.84	0.89
7	10,984	38	0.41	0.42	0.46	0.96	0.82
8	12,129	41	0.41	0.04	0.51	0.84	0.93
9	11,721	38	0.39	0.28	0.40	0.82	0.82
10	10,905	38	0.42	0.29	0.23	0.77	0.83
11	11,395	39	0.41	0.23	0.40	0.75	0.87
12	11,414	39	0.41	0.31	0.25	0.82	0.82
13	12,768	44	0.41	0.23	0.39	0.71	0.80
14	14,372	48	0.40	0.11	0.46	0.81	0.86
15	11,841	42	0.43	0.12	0.48	0.59	0.99
16	12,270	41	0.40	0.28	0.46	0.51	0.96
17	12,014	42	0.42	0.26	0.32	0.72	0.83
18	11,668	41	0.42	0.48	0.31	0.87	0.72
19	10,006	34	0.41	0.11	0.30	0.61	0.68
20	9,097	31	0.41	0.19	0.28	0.63	0.73
21	10,489	36	0.41	0.25	0.38	0.73	0.80
22	10,165	35	0.41	0.31	0.25	0.73	0.61
23	10,645	23	0.26	0.30	0.32	0.73	0.72
24	10,725	0	0.00	0.14	0.40	0.57	0.43
25	10,690	0	0.00	0.39	0.20	0.39	0.17
26	9,878	0	0.00	0.18	0.19	0.11	0.10
27	9,065	0	0.00	0.13	0.21	0.12	0.25
28	10,609	0	0.00	0.30	0.25	0.30	0.32
29	9,151	0	0.00	0.11	0.20	0.21	0.34
30	9,065	0	0.00	0.29	0.35	0.25	0.32
31							
Total	321,419	852					
Avg.	10,714	28	0.31	0.27	0.34	0.64	0.69

*Example: Sodium Fluoride, Sodium Fluorosilicate (Sodium Silicofluoride), and

Fluorosilicic Acid (Hydrofluosilicic Acid)

It is required that this report be received by the 10th of the following month.

SEND TO: OSDH-Dental Health Services AND

Dept of Environmental Quality

1000 N.E. Tenth Street

PO Box 1677


Oklahoma City, OK 73117-1299

Oklahoma City, OK 73101-1677

I hereby certify the above to be

correct to the best of my knowledge.

Signed



Title: Water Plant Manager

City Broken Arrow

ODH Form No. 561 / DEQ Form 631-001

Notes: Fluoride feed shut down for repairs starting on the 23rd.

Public Water System Name: COBA Water Treatment Plant

Month: April

PWS ID No.:

OK 1021508

Year: 2025

Date	Distribution Total Chlorine mg/L A.M. Sample				Distribution Total Chlorine mg/L P.M. Sample			
	Time	Location	mg/L	Sampler	Time	Location	mg/L	Sampler
1	9:24	8017 S. Peach Ave.	3.40	ML	12:22	8017 S. Date Ave.	2.70	ML
2	10:21	1729 S. Pine Ave.	2.40	ML	12:25	7900 E. Norman St.	3.20	ML
3	8:37	6103 S 15th Pl	3.10	ML	12:24	738 N 4th St	3.00	ML
4	10:13	601 S 71st St	3.20	ML	13:00	1700 S Walnut Ave	2.90	ML
5	11:39	2700 N. 7th St.	2.60	T.R.	12:28	1544 E. Freeport St.	2.90	T.R.
6	11:55	2909 E. Montpelier St.	3.00	R.M.	12:30	1729 S. Pine Ave.	2.80	R.M.
7	09:39	13725 S. 124th E. Ave.	2.70	M.L.	12:46	1116 W. Granger St.	2.80	M.L.
8	09:48	4001 S. Chestnut Ave.	3.30	M.L.	12:41	1301 N. 53rd St.	3.20	M.L.
9	07:48	3301 N. 5th St.	3.20	J.S.	12:23	1401 S. Oak Ave.	3.50	J.S.
10	07:22	800 E. Seattle St.	3.10	M.L.	12:05	1005 N. Willow Ave.	2.90	M.L.
11	8:22	1909 W Rockport St.	3.00	A.R.	12:30	317 W Quannah St.	2.90	A.R.
12	11:34	1116 W Grenger St.	3.10	ME	12:15	1817 S Willow Ave.	3.10	ME
13	11:47	36500 E. 66th St. S.	3.50	R.M.	18:25	6057 S. 353rd E. Ave.	2.90	R.M.
14	10:11	8017 S. Peach Ave.	3.10	M.L.	12:15	702 E. Mason Dr.	3.20	M.L.
15	08:41	4121 E. Omaha St.	2.70	M.L.	12:54	1903 W. Rockport Pl.	3.00	M.L.
16	8:39	708 W. Waco St.	3.10	ML	12:16	601 N. Palm Ave.	3.10	ML
17	07:32	4301 S. Aspen Pl.	3.30	M.L.	14:42	1516 N. 20th St.	3.50	A.R.
18	11:37	2700 N. 7th St.	3.20	T.R.	12:30	1021 Wesley Dr.	3.60	T.R.
19	11:35	2513 E Dallas St.	3.20	ME	12:22	3621 S Elm Pl.	3.50	ME
20	10:00	7900 E. Norman	3.60	R.M.	14:18	36500 E. 66th St. S.	3.60	J.B.
21	10:12	322 W. DEtroit St.	3.20	ML	12:03	608 E. Pensacola St.	2.80	ML
22	8:47	721 W. Atlanta Ct.	3.00	ML	12:48	2909 E. Montpelier St.	3.10	ML
23	9:03	1116 W. Granger St.	3.10	ML	12:11	3627 S. Fir Blvd	3.30	ML
24	8:42	513 S. 63rd Pl.	3.00	ML	1:26	5405 S. Hickory Ave.	3.00	ML
25	08:56	637 S. Fir Ave.	2.90	M.L.	12:43	1515 E. New Orleans Pl.	3.40	M.L.
26	11:35	2401 W. Omaha St.	3.10	T.R.	12:32	1423 E. Concord Pl.	3.50	T.R.
27	11:54	2909 E. Montpelier St.	3.30	J.B.	12:31	3706 S. Orange Cir.	3.10	J.B.
28	08:35	5005 S. Lions Ave.	3.10	M.L.	12:38	804 N. 1st St.	3.20	M.L.
29	07:26	7203 S. Dennis Blvd.	3.30	M.L.	12:45	1209 W. Glendale St.	2.50	M.L.
30	9:37	2017 W. Rockport St.	2.90	ML	12:08	2631 W. Washington Pl.	2.90	ML

Average 3.09

Min. 2.40

Max. 3.60

Average 3.10

Min. 2.50

Max. 3.60