

**National Pollutant Discharge Elimination System (NPDES)  
Oklahoma Department of Environmental Quality Discharge Monitoring Report (DMR)**

**PERMITTEE NAME:** City of Broken Arrow  
**MAILING ADDRESS:** P.O. Box 610  
 Broken Arrow, OK 74013  
**FACILITY:** Broken Arrow WWT  
**LOCATION:** NESESES11T17NR14EIM  
 Broken Arrow, OK 74013

**PERMIT NUMBER:** OK0040053  
**MONITORING POINT:** 001A  
**Monitoring Period:** 2024-11-01 To: 2024-11-30

**COUNTY:** Tulsa  
**NO DISCHARGE FROM SITE:** ( )

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
		Average	Maximum		Minimum	Average	Maximum				
BOD, 5-DAY (20 DEG. C) PARAM CODE: 00310 Stage Code: 1 Effluent Gross	Sample Measurement	156.48	*****	26 lbs/day	*****	2.60	3.04	19 mg/l	0	Five Per Week	COMP12
	Permit Requirement	2001.6 Monthly Average	*****		*****	30 Monthly Average	45 Weekly Average				Five Per Week
PH PARAM CODE: 00400 Stage Code: 1 Effluent Gross	Sample Measurement	*****	*****		7.0	*****	7.4	12 S.U.	0	Daily	GRAB
	Permit Requirement	*****	*****		6.5 Minimum	*****	9.0 Maximum				Daily
SOLIDS, TOTAL SUSPENDED PARAM CODE: 00530 Stage Code: 1 Effluent Gross	Sample Measurement	148.74	*****	26 lbs/day	*****	2.38	3.06	19 mg/l	0	Five Per Week	COMP12
	Permit Requirement	2001.6 Monthly Average	*****		*****	30 Monthly Average	45 Weekly Average				Five Per Week
FLOW, IN CONDUIT OR THRU TREATMENT PLANT PARAM CODE: 50050 Stage Code: 1 Effluent Gross	Sample Measurement	6.758	13.285	03 MGD	*****	*****	*****		0	Daily	TOTALZ
	Permit Requirement	Report Monthly Average	Report Maximum Daily		*****	*****	*****				Daily
CHLORINE, TOTAL RESIDUAL PARAM CODE: 50060 Stage Code: A Disinfection, Process Complete	Sample Measurement	*****	*****		*****	*****	5.67	19 mg/l	1	Daily	GRAB
	Permit Requirement	*****	*****		*****	*****	0.099 Instantaneous Maximum				Daily
E.COLI PARAM CODE: 51040 Stage Code: 1 Effluent Gross	Sample Measurement	*****	*****		*****	2.6	10.9	30 MPN/100mL	0	Weekly	GRAB
	Permit Requirement	*****	*****		*****	630 Geometric Mean	2030 Maximum Daily				Weekly
SOLIDS, TOTAL DISSOLVED-180 DEG.C PARAM CODE: 70300 Stage Code: 1 Effluent Gross	Sample Measurement	13193	*****	26 lbs/day	*****	380	380	19 mg/l	0	Monthly	COMP12
	Permit Requirement	77929 Monthly Average	*****		*****	1168 Monthly Average	1168 Maximum Daily				Monthly

Name/Title of Principal Executive Officer Or Authorized Agent  WRF Manager	I CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHMENTS WERE PREPARED UNDER MY DIRECTION OR SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY GATHER AND EVALUATE THE INFORMATION SUBMITTED. BASED ON MY INQUIRY OF THE PERSON OR PERSONS WHO MANAGE THE SYSTEM, OR THOSE PERSONS DIRECTLY RESPONSIBLE FOR GATHERING THE INFORMATION, THE INFORMATION SUBMITTED IS, TO THE BEST OF MY KNOWLEDGE AND BELIEF, TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.	Signature of Principal Executive Officer Or Authorized Agent	Telephone No
		David Handy	539-367-5873

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

**National Pollutant Discharge Elimination System (NPDES)  
Oklahoma Department of Environmental Quality Discharge Monitoring Report (DMR)**

**PERMITTEE NAME:** City of Broken Arrow  
**MAILING ADDRESS:** P.O. Box 610  
 Broken Arrow, OK 74013  
**FACILITY:** Broken Arrow WWT  
**LOCATION:** NESESES11T17NR14EIM  
 Broken Arrow, OK 74013

**PERMIT NUMBER:** OK0040053

**MONITORING POINT:** 001A

**COUNTY:** Tulsa

**Monitoring Period:** 2024-11-01 To: 2024-11-30

**NO DISCHARGE FROM SITE:** ( )

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
		Average	Maximum		Minimum	Average	Maximum				
MERCURY, TOTAL (AS HG)	Sample Measurement	0.0033	*****	26 lbs/day	*****	< 0.05	< 0.05	28 ug/l	0	Monthly	COMP12
PARAM CODE: 71900 Stage Code: 1 Effluent Gross	Permit Requirement	0.0635 Monthly Average	*****		*****	0.952 Monthly Average	1.9 Maximum Daily				Monthly

<b>Name/Title of Principal Executive Officer Or Authorized Agent</b>	I CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHMENTS WERE PREPARED UNDER MY DIRECTION OR SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY GATHER AND EVALUATE THE INFORMATION SUBMITTED. BASED ON MY INQUIRY OF THE PERSON OR PERSONS WHO MANAGE THE SYSTEM, OR THOSE PERSONS DIRECTLY RESPONSIBLE FOR GATHERING THE INFORMATION, THE INFORMATION SUBMITTED IS, TO THE BEST OF MY KNOWLEDGE AND BELIEF, TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.	<b>Signature of Principal Executive Officer Or Authorized Agent</b>	<b>Telephone No</b>
WRF Manager		David Handy	539-367-5873

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

**National Pollutant Discharge Elimination System (NPDES)  
Oklahoma Department of Environmental Quality Discharge Monitoring Report (DMR)**

**PERMITTEE NAME:** City of Broken Arrow  
**MAILING ADDRESS:** P.O. Box 610  
 Broken Arrow, OK 74013  
**FACILITY:** Broken Arrow WWT  
**LOCATION:** NESESES11T17NR14EIM  
 Broken Arrow, OK 74013

**PERMIT NUMBER:** OK0040053  
**MONITORING POINT:** TX1A  
**Monitoring Period:** 2024-11-01 To: 2024-11-30

**COUNTY:** Tulsa  
**NO DISCHARGE FROM SITE:** ( )

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
		Average	Maximum		Minimum	Average	Maximum				
PH PARAM CODE: 00400 Stage Code: 1 Effluent Gross	Sample Measurement	*****	*****		*9	*****	*9	12 S.U.	0	Monthly	MEASRD
	Permit Requirement	*****	*****		Report Minimum Daily	*****	Report Maximum Daily				
NITROGEN, AMMONIA TOTAL (AS N) PARAM CODE: 00610 Stage Code: 1 Effluent Gross	Sample Measurement	*****	*****		*9	*9	*9	19 mg/l	0	Monthly	COMP24
	Permit Requirement	*****	*****		Report Minimum Daily	Report Monthly Average	Report Maximum Daily				
WHOLE EFFLUENT TOXICITY PARAM CODE: 22414 Stage Code: 1 Effluent Gross	Sample Measurement	*****	*****		*9	*****	*****	23 %	0	Monthly	COMP24
	Permit Requirement	*****	*****		100 48 Hour Minimum	*****	*****				
LC50 STATRE 48HR ACU PIMEPHALES PARAM CODE: TAM6C Stage Code: 1 Effluent Gross	Sample Measurement	*****	*****		*9	*****	*****	23 %	0	Monthly	COMP24
	Permit Requirement	*****	*****		Report 48 Hour Minimum	*****	*****				
LC50 STATRE 48HR ACU P. PROMELAS PARAM CODE: TIM6C Stage Code: 1 Effluent Gross	Sample Measurement	*****	*****		*9	*****	*****	9A pass (0)/fail(1)	0	Monthly	COMP24
	Permit Requirement	*****	*****		Report 48 Hour Minimum	*****	*****				
%MORTALITY 48HR ACUTE P. PROMELAS TEST PARAM CODE: TJM6C Stage Code: 1 Effluent Gross	Sample Measurement	*****	*****		*9	*****	*****	23 %	0	Monthly	COMP24
	Permit Requirement	*****	*****		Report 48 Hour Minimum	*****	*****				

Name/Title of Principal Executive Officer Or Authorized Agent  WRF Manager	I CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHMENTS WERE PREPARED UNDER MY DIRECTION OR SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY GATHER AND EVALUATE THE INFORMATION SUBMITTED. BASED ON MY ENQUIRY OF THE PERSON OR PERSONS WHO MANAGE THE SYSTEM, OR THOSE PERSONS DIRECTLY RESPONSIBLE FOR GATHERING THE INFORMATION, THE INFORMATION SUBMITTED IS, TO THE BEST OF MY KNOWLEDGE AND BELIEF, TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.	Signature of Principal Executive Officer Or Authorized Agent	Telephone No
		David Handy	539-367-5873

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

**GENERAL REPORT COMMENT:**

---

Nov. 15 - Clarifier weir was cleaned with 12.5% sodium hypochlorite to remove heavy algae.