

City of Broken Arrow WTP Monthly Operational Report Summary
Water Treatment Plant PWSID# OK 1021508

Reporting Period: [February] [2026]



Operating Data Summary

Water Production (MG)

	Month	Average Day
Raw Water Treated	276.12	9.9
Finished Water	267.09	9.5

Finished Water Turbidity:

	No. Samples	% of Total Samples
Greater than 0.5 NTU	0	0.00
Greater than 0.3 NTU	0	0.00
Greater than 0.1 NTU	0	0.00
Total No. of Turbidity Samples	168	
Highest Turbidity Reading	0.035	
No. Samples > 1 NTU	0	
No. Samples > 5 NTU	0	

Monthly Chemical Usage (Non-Membrane Usage)

Chemical	Total lbs	lbs/Finished MG
Sodium Hypochlorite	15,958	853.5
Salt (for hypo generation)	47,873	2,560.5
Liquid Ammonium Sulfate	2,517	9.0
Sodium Permanganate	1,196	2.3
Aluminum Chlorohydrate	67,272	45.1
Sodium Hydroxide	1,819	2.6
Hydrofluosilicic Acid	0	0.0

Monthly Costs

	Total	\$/Finished MG	\$/1000 gal
Plant Electricity	\$73,288.55	\$274.39	\$0.2744
Total Chemical	\$70,787.18	\$265.03	\$0.2650
Total Labor	\$120,128.46	\$449.76	\$0.4498
Services	\$24,484.80	\$91.67	\$0.0917
Materials and Supplies	\$26,133.90	\$97.85	\$0.0978
Equipment Expenses	\$21,922.35	\$82.08	\$0.0821
Total	\$336,745.24	\$1,260.78	\$1.2608

Total Chlorine Residual:

	No. Samples
Total Chlorine Residual <2.0 mg/L Leaving Plant	0

Individual Membrane Unit Turbidity Checklist

	YES/NO
1. IS TURBIDITY FROM EACH INDIVIDUAL MEMBRANE UNIT RECORDED EVERY 15 MINUTES?	<input type="checkbox"/> YES
2. DID ANY SINGLE MEMBRANE UNIT EXCEED 2.0 NTU IN TWO CONSECUTIVE 15 MINUTE PERIODS?	<input type="checkbox"/> NO
No, Go to Question 3.	
Yes, What date was the membrane profile completed? _____	
DID THIS SAME MEMBRANE UNIT EXCEED 2.0 NTU IN 2 CONSECUTIVE 15-MIN PERIODS DURING THE LAST MONTH?	<input type="checkbox"/>
No, Go to Question 3.	
Yes, Schedule Comprehensive Performance Evaluation (CPE) with DEQ.	
3. DID ANY SINGLE MEMBRANE UNIT EXCEED 1.0 NTU IN TWO CONSECUTIVE 15 MINUTE PERIODS?	<input type="checkbox"/> NO
No, Go to Question 4.	
Yes, What date was the filter profile completed? _____	
DID THIS SAME MEMBRANE UNIT FILTER EXCEED 1.0 NTU IN 2 CONSECUTIVE 15-MIN PERIODS DURING THE LAST 2 MONTHS?	<input type="checkbox"/>
No, Go to Question 4.	
Yes, What date was the membrane self-assessment completed? _____	
4. DID ANY SINGLE MEMBRANE UNIT EXCEED 0.5 NTU IN 2 CONSECUTIVE 15-MIN PERIODS AT THE END OF 4 HRS OF OPERATION?	<input type="checkbox"/> NO
No, You are finished with the checklist.	
Yes, What date was the membrane profile completed? _____	

* IF ANY OF QUESTIONS 2 THROUGH 4 ARE CHECKED "YES", YOU MUST COMPLETE THE TURBIDITY TRIGGER EVALUATION FORM AND ATTACH TO THIS MOR.

I hereby certify the above to be correct to the best of my knowledge:

Notes: Fluoride system offline for leak repairs to bulk tank pipes and transfer system.

Signed: Loe Ann Fisher 3/10/2026
Date

Title: Water Plant Manager

Operator Certificate No. 25369

Date	Water Production and Recycle Flows				
	Raw Water Pumped to Pre-Sed Basins (MG)	Raw Water Treated (MG)	Finished Water Delivered (MG)	Reverse Filtration Water Used (MG)	Lagoon Decant Water Pumped (MG)
1	10.85	10.04	9.98		0.52
2	10.85	10.78	10.16		0.54
3	10.82	10.25	9.99		0.56
4	5.96	9.58	9.38		0.62
5	0.00	9.59	9.36		0.70
6	0.00	9.49	9.32		0.51
7	0.00	10.13	9.35		0.42
8	10.88	9.28	9.14		0.48
9	11.24	10.02	9.45		0.59
10	10.83	10.05	9.94		0.58
11	11.26	10.09	9.32		0.56
12	11.26	9.79	9.44		0.55
13	11.23	9.55	9.45		0.54
14	11.23	8.79	9.26		0.54
15	11.21	9.66	8.50		0.53
16	11.20	9.29	9.59		0.53
17	11.18	10.65	10.21		0.47
18	11.18	10.17	9.59		0.45
19	11.17	9.48	9.59		0.64
20	11.17	10.20	9.57		0.67
21	11.16	10.15	9.26		0.55
22	11.17	9.06	9.03		0.49
23	11.15	9.63	9.62		0.49
24	11.14	10.13	9.73		0.50
25	11.13	9.74	9.49		0.53
26	11.14	10.61	10.22		0.73
27	11.06	10.82	9.85		0.58
28	11.06	9.09	9.30		0.41
29					
30					
31					
TOTAL	272.53	276.12	267.09	0.00	15.26
AVG	9.73	9.86	9.54	#DIV/0!	0.54
MAX	11.26	10.82	10.22	0.00	0.73
MIN	0.00	8.79	8.50	0.00	0.41

Public Water System Name: COBA Water Treatment Plant
 PWS ID No.: OK 1021508

Month: February
 Year: 2026

TOTAL CHEMICAL COST:	\$70,787		
Cost Per MG Treated	\$256.37	Cost Per MG Delivered	\$265.03
Million Gallons Treated	276.12	Million Gallons Delivered	267.09

Non-Membrane System Chemical Usage

Date	Sodium Hypochlorite (CL) NaClO		Liquid Ammonium Sulfate (LAS)		Sodium Permanganate (SP)		Aluminum Chlorohydrate (ACH)		Sodium Hydroxide (SH)		Hydrofluosilicic Acid (HFS)	
	gal/day	lb/day	gal/day	lb/day	gal/day	lb/day	gal/day	lb/day	gal/day	lb/day	gal/day	lb/day
1	8,154	570.75	89.8	94.06	24.6	47.61	438	2449.46	32.2	83.79	0.0	0.00
2	8,594	601.56	96.4	101.03	24.6	47.62	471	2631.97	34.7	90.38	0.0	0.00
3	7,877	551.38	87.6	91.76	24.5	47.48	429	2398.73	31.8	82.80	0.0	0.00
4	8,130	569.12	90.4	94.71	12.8	24.72	443	2476.02	32.7	85.33	0.0	0.00
5	7,595	531.65	84.4	88.42	0.0	0.00	415	2317.61	30.7	79.93	0.0	0.00
6	7,442	520.96	83.7	87.72	0.0	0.00	410	2290.20	30.4	79.32	0.0	0.00
7	7,882	551.77	89.0	93.27	0.0	0.00	438	2446.14	32.3	84.13	0.0	0.00
8	7,175	502.24	81.2	85.07	25.5	49.26	398	2221.40	29.6	77.10	0.0	0.00
9	7,923	554.61	90.0	94.29	25.5	49.34	445	2485.35	32.8	85.60	0.0	0.00
10	7,868	550.79	87.0	91.13	24.6	47.52	432	2415.06	31.7	82.72	0.0	0.00
11	8,147	570.30	88.2	92.42	25.5	49.42	440	2461.42	32.4	84.35	0.0	0.00
12	7,590	531.30	82.2	86.11	25.5	49.41	411	2298.68	30.3	78.92	0.0	0.00
13	7,983	558.79	86.5	90.62	25.5	49.30	432	2415.01	31.8	82.94	0.0	0.00
14	7,714	539.98	80.8	84.70	25.5	49.28	403	2249.30	29.8	77.74	0.0	0.00
15	7,783	544.81	81.5	85.37	25.4	49.21	407	2274.64	30.1	78.38	0.0	0.00
16	8,083	565.80	83.7	87.69	25.4	49.17	419	2338.71	22.4	58.37	0.0	0.00
17	8,849	619.46	91.4	95.79	25.4	49.07	455	2541.46	17.6	45.90	0.0	0.00
18	8,814	617.01	89.2	93.45	25.4	49.07	452	2527.29	17.4	45.39	0.0	0.00
19	8,336	583.49	80.8	84.67	25.3	49.01	413	2306.43	16.1	42.06	0.0	0.00
20	9,087	636.06	87.5	91.69	25.3	49.01	449	2509.42	17.4	45.35	0.0	0.00
21	8,347	584.32	81.6	85.47	25.3	49.00	419	2339.09	16.3	42.55	0.0	0.00
22	7,797	545.80	75.9	79.56	25.4	49.05	389	2172.41	15.3	39.90	0.0	0.00
23	8,804	616.29	86.7	90.81	25.3	48.95	443	2475.58	17.2	44.88	0.0	0.00
24	8,442	590.93	83.9	87.88	25.3	48.90	430	2402.71	16.7	43.52	0.0	0.00
25	8,731	611.15	87.1	91.23	25.3	48.87	448	2501.42	17.2	44.94	0.0	0.00
26	8,439	590.70	86.0	90.10	25.3	48.90	441	2464.21	17.1	44.45	0.0	0.00
27	8,796	615.69	92.0	96.38	25.1	48.54	473	2645.59	18.1	47.19	0.0	0.00
28	7,584	530.91	78.0	81.77	25.1	48.57	397	2216.42	15.6	40.64	0.0	0.00
29												
30												
31												
TOTAL	227,966	15,958	2,402	2,517	618	1,196	12,039	67,272	698	1,819	0	0
AVG	8,142	569.91	86	89.90	22	42.72	430	2402.56	25	64.95	0	0.00
MAX	9,087	636.06	96	101.03	26	49.42	473	2645.59	35	90.38	0	0.00
MIN	7,175	502.24	76	79.56	0	0.00	389	2172.41	15	39.90	0	0.00
COST	\$8,990.75		\$4,350.09		\$8,828.52		\$47,090.21		\$1,527.60		\$0.00	
\$/MG	\$32.56		\$15.75		\$31.97		\$170.54		\$5.53		\$0.00	

Public Water System Name: COBA Water Treatment Plant
 PWS ID No.: OK 1021508

Month: February
 Year: 2026

Date	pH (by Continuous Reading Analyzers)				Hardness and Alkalinity - Finished Water Grab Samples							CaCO ₃ Stability
	Membrane Filtrate		Finished Water		Hardness (ppm)		Alkalinity (ppm as CaCO ₃)					
	Daily Max	Daily Min	Daily Max	Daily Min	AM	PM	Phenol AM	Phenol PM	Total AM	Total PM		
1	7.8	7.8	8.1	8.0	191.00	196.00	0.00	0.00	131.00	129.00	8.00	
2	7.8	7.8	8.1	8.0	193.00	186.00	0.00	0.00	129.00	130.00	9.00	
3	7.8	7.8	8.1	8.1	191.00	186.00	0.00	0.00	129.00	129.00	7.00	
4	14.0	1.0	8.1	8.0	190.00	185.00	0.00	0.00	131.00	131.00	1.00	
5	7.9	7.9	8.0	8.0	193.00	186.00	0.00	0.00	132.00	130.00	8.00	
6	7.9	7.9	8.0	8.0	188.00	192.00	0.00	0.00	131.00	126.00	2.00	
7	7.9	7.9	8.0	8.0	189.00	192.00	0.00	0.00	132.00	129.00	9.00	
8	7.9	7.9	8.1	8.0	178.00	190.00	0.00	0.00	132.00	130.00	2.00	
9	8.0	7.9	8.1	8.0	193.00	192.00	0.00	0.00	133.00	131.00	8.00	
10	8.0	7.9	8.1	8.1	197.00	194.00	0.00	0.00	131.00	130.00	4.00	
11	8.0	8.0	8.1	8.1	194.00	182.00	0.00	0.00	132.00	129.00	8.00	
12	8.0	8.0	8.1	8.1	197.00	191.00	0.00	0.00	134.00	130.00	12.00	
13	8.0	8.0	8.1	8.1	199.00	194.00	0.00	0.00	140.00	132.00	8.00	
14	8.0	8.0	8.1	8.1	196.00	199.00	0.00	0.00	134.00	134.00	6.00	
15	8.0	8.0	8.1	8.1	195.00	195.00	0.00	0.00	135.00	132.00	12.00	
16	8.0	8.0	8.1	8.1	195.00	195.00	0.00	0.00	132.00	134.00	12.00	
17	8.5	0.0	8.1	8.0	196.00	195.00	0.00	0.00	133.00	136.00	6.00	
18	7.9	7.9	8.0	8.0	198.00	203.00	0.00	0.00	133.00	132.00	12.00	
19	7.9	7.9	8.0	8.0	198.00	195.00	0.00	0.00	134.00	131.00	8.00	
20	7.9	7.9	8.0	8.0	200.00	199.00	0.00	0.00	134.00	132.00	7.00	
21	7.9	7.9	8.0	8.0	198.00	199.00	0.00	0.00	134.00	132.00	8.00	
22	7.9	7.9	8.0	8.0	199.00	196.00	0.00	0.00	135.00	135.00	6.00	
23	7.9	7.8	8.0	8.0	201.00	199.00	0.00	0.00	133.00	130.00	4.00	
24	7.9	7.8	8.0	8.0	204.00	199.00	0.00	0.00	130.00	136.00	14.00	
25	7.9	7.8	8.0	8.0	207.00	195.00	0.00	0.00	133.00	130.00	9.00	
26	7.9	7.9	8.0	8.0	203.00	204.00	0.00	0.00	132.00	134.00	1.00	
27	7.9	7.8	8.0	8.0	203.00	200.00	0.00	0.00	134.00	135.00	7.00	
28	7.9	7.8	8.0	8.0	203.00	207.00	0.00	0.00	136.00	133.00	4.00	
29												
30												
31												
AVG					196	195	0	0	133	132	7	
MAX	14.0	8.0	8.1	8.1	207	207	0	0	140	136	14	
MIN	7.8	0.0	8.0	8.0	178	182	0	0	129	126	1	

Public Water System Name: COBA Water Treatment Plant
 PWS ID No.: OK 1021508

Month: February
 Year: 2026

Date	Turbidity (NTU) Continuous Reading Analyzers						Chlorine Residual (Total or Free as Noted, mg/L) Continuous Reading Analyzers					
	Finished Water (Highest Reading in 4-hour Period)						Finished Water Total Chlorine (Min. in 4 Hour Period)					
	12:00 AM	4:00 AM	8:00 AM	12:00 PM	4:00 PM	8:00 PM	12:00 AM	4:00 AM	8:00 AM	12:00 PM	4:00 PM	8:00 PM
1	0.02	0.02	0.02	0.02	0.02	0.02	3.70	3.74	3.74	3.75	3.74	3.72
2	0.02	0.02	0.02	0.02	0.02	0.02	3.68	3.69	3.66	3.69	3.69	3.69
3	0.02	0.02	0.02	0.02	0.02	0.02	3.64	3.68	3.67	3.66	3.65	3.65
4	0.02	0.02	0.02	0.02	0.02	0.02	3.71	3.64	3.64	3.65	3.68	3.70
5	0.02	0.02	0.02	0.02	0.02	0.02	3.66	3.71	3.71	3.71	3.70	3.68
6	0.02	0.02	0.02	0.02	0.02	0.02	3.64	3.66	3.65	3.65	3.64	3.64
7	0.02	0.02	0.02	0.02	0.02	0.02	3.64	3.66	3.66	3.66	3.66	3.65
8	0.02	0.02	0.02	0.02	0.02	0.02	3.57	3.63	3.61	3.61	3.58	3.58
9	0.02	0.02	0.02	0.02	0.02	0.02	3.56	3.58	3.57	3.58	3.57	3.56
10	0.02	0.02	0.02	0.02	0.03	0.02	3.56	3.55	3.54	3.54	3.56	3.55
11	0.02	0.02	0.02	0.02	0.02	0.02	3.65	3.58	3.64	3.66	3.68	3.66
12	0.02	0.02	0.02	0.02	0.02	0.02	3.56	3.64	3.62	3.61	3.59	3.56
13	0.02	0.02	0.02	0.02	0.03	0.02	3.54	3.56	3.56	3.55	3.55	3.55
14	0.02	0.02	0.02	0.02	0.02	0.02	3.53	3.54	3.56	3.56	3.55	3.54
15	0.02	0.02	0.02	0.02	0.02	0.02	3.51	3.52	3.52	3.52	3.51	3.51
16	0.02	0.02	0.02	0.02	0.02	0.02	3.56	3.51	3.50	3.48	3.49	3.52
17	0.02	0.02	0.02	0.02	0.02	0.02	3.57	3.59	3.62	3.61	3.61	3.59
18	0.03	0.02	0.02	0.02	0.02	0.02	3.56	3.57	3.58	3.59	3.56	3.56
19	0.02	0.02	0.02	0.02	0.02	0.02	3.55	3.55	3.53	3.51	3.52	3.51
20	0.02	0.02	0.02	0.03	0.02	0.02	3.69	3.57	3.60	3.61	3.65	3.69
21	0.02	0.02	0.02	0.02	0.02	0.02	3.60	3.68	3.65	3.63	3.61	3.61
22	0.02	0.02	0.02	0.03	0.02	0.02	3.60	3.62	3.60	3.59	3.59	3.59
23	0.02	0.02	0.02	0.02	0.02	0.02	3.67	3.60	3.61	3.63	3.65	3.66
24	0.03	0.04	0.02	0.02	0.02	0.02	3.65	3.68	3.70	3.67	3.68	3.67
25	0.02	0.02	0.02	0.02	0.02	0.02	3.67	3.66	3.66	3.66	3.66	3.65
26	0.02	0.03	0.02	0.02	0.02	0.02	3.57	3.69	3.71	3.68	3.64	3.61
27	0.02	0.02	0.02	0.02	0.03	0.02	3.55	3.58	3.58	3.57	3.56	3.49
28	0.02	0.02	0.02	0.02	0.02	0.02	3.43	3.55	3.53	3.51	3.48	3.47
29												
30												
31												
AVG	0.02	0.02	0.02	0.02	0.02	0.02	3.6	3.6	3.6	3.6	3.6	3.6
MAX	0.03	0.04	0.02	0.03	0.03	0.02	3.7	3.7	3.7	3.8	3.7	3.7
MIN	0.02	0.02	0.02	0.02	0.02	0.02	3.4	3.5	3.5	3.5	3.5	3.5

Finished Water Turbidity Summary and Statistics

	No. of Samples	Percent of Total Samples
Turbidity Greater Than 0.5 NTU	0	0
Turbidity Greater Than 0.3 NTU	0	0
Turbidity Greater Than 0.1 NTU	0	0

Total Number of Turbidity Samples	168
-----------------------------------	-----

PWSID 1021508

SYSTEM COBA WTP

MONTH February

*Type of Material Applied

Hydrofluosilicic Acid

YEAR 2026

Date	Water Treated 1,000s of Gallons	APPLIED		RESIDUAL F, ppm (RAW)		RESIDUAL F, ppm (FINISHED WATER)	
		LBS/DAY	PPM of F	AM	PM	AM	PM
1	9,976	0	0.00	0.29	0.56	0.14	0.13
2	10,159	0	0.00	0.30	0.13	0.15	0.12
3	9,987	0	0.00	0.49	0.42	0.24	0.26
4	9,379	0	0.00	0.27	0.27	0.15	0.15
5	9,362	0	0.00	0.29	0.51	0.16	0.24
6	9,321	0	0.00	0.25	0.39	0.21	0.16
7	9,352	0	0.00	0.42	0.49	0.27	0.17
8	9,136	0	0.00	0.30	0.53	0.18	0.33
9	9,450	0	0.00	0.31	0.29	0.22	0.24
10	9,935	0	0.00	0.35	0.36	0.10	0.23
11	9,316	0	0.00	0.33	0.38	0.16	0.29
12	9,439	0	0.00	0.33	0.39	0.45	0.18
13	9,454	0	0.00	0.47	0.47	0.34	0.25
14	9,265	0	0.00	0.39	0.56	0.18	0.38
15	8,505	0	0.00	0.45	0.38	0.28	0.27
16	9,595	0	0.00	0.34	0.54	0.29	0.37
17	10,205	0	0.00	0.33	0.08	0.21	0.00
18	9,585	0	0.00	0.61	0.76	0.36	0.60
19	9,594	0	0.00	0.30	0.43	0.19	0.36
20	9,570	0	0.00	0.39	0.33	0.27	0.21
21	9,259	0	0.00	0.32	0.46	0.20	0.31
22	9,032	0	0.00	0.39	0.46	0.44	0.41
23	9,623	0	0.00	0.31	0.36	0.14	0.35
24	9,732	0	0.00	0.45	0.36	0.43	0.18
25	9,487	0	0.00	0.31	0.39	0.23	0.44
26	10,221	0	0.00	0.40	0.32	0.30	0.23
27	9,853	0	0.00	0.30	0.42	0.19	0.29
28	9,301	0	0.00	0.38	0.47	0.24	0.21
29							
30							
31							
Total	267,093	0					
Avg.	9,539	0	0.00	0.36	0.41	0.24	0.26

*Example: Sodium Fluoride, Sodium Fluorosilicate (Sodium Silicofluoride), and Fluorosilicic Acid (Hydrofluosilicic Acid)

It is required that this report be received by the 10th of the following month.

SEND TO: OSDH-Dental Health Services AND

Dept of Environmental Quality

1000 N.E. Tenth Street

PO Box 1677

Oklahoma City, OK 73117-1299

Oklahoma City, OK 73101-1677

I hereby certify the above to be

correct to the best of my knowledge.

Signed

Law Ann Fisher

Title: Water Plant Manager

City Broken Arrow

ODH Form No. 561 / DEQ Form 631-001

Notes: Fluoride system offline for repairs to leaks on bulk tank pipes and transfer system.

Public Water System Name: COBA Water Treatment PlantMonth: February

PWS ID No.:

OK 1021508Year: 2026

Date	Distribution Total Chlorine mg/L A.M. Sample				Distribution Total Chlorine mg/L P.M. Sample			
	Time	Location	mg/L	Sampler	Time	Location	mg/L	Sampler
1	11:38	8017 S. Peach Ave.	3.60	T.R.	12:42	2700 N. 7th St.	3.50	T.R.
2	08:46	3706 S. Orange Cir.	2.80	M.L.	12:28	2909 E. Montpelier St.	3.60	M.L.
3	09:25	1301 N. 53rd St.	3.40	M.L.	13:32	5005 S. Lions Ave.	3.60	M.L.
4	8:12	515 W. Quannah Pl	3.30	ML	12:53	322 W. Detroit St.	3.80	ML
5	10:12	1728 S. Pine Ave.	3.80	M.L.	14:28	7029 S. Indianwood Ct.	3.20	M.L.
6	8:39	3329 W Freeport St.	3.20	ML	14:40	2509 E Oakland St.	3.50	ML
7	11:44	702 E. Mason Dr.	3.70	S.B	12:17	1200 E. Dover St.	3.70	S.B
8	11:55	2909 E. Montpelier St.	3.20	R.M.	12:27	1726 S. Pine Ave.	3.70	R.M.
9	9:11	1116 W. Granger St.	3.40	ML	12:00	1700 S. Walnut Ave.	3.80	ML
10	8:32	2813 W. Oakland St.	3.40	ML	12:49	5005 S. Lions Ave.	3.50	ML
11	8:27	3706 S.Orange Cir.	2.90	ML	12:02	1817 S. Date Ave.	3.40	ML
12	9:21	1707 D. Fesert Palm Pl.	3.30	ML	1:23	1901 N. 4th St.	3.60	ML
13	10:32	3116 W Tucson Ct.	3.50	AR	12:15	600 W Madison	3.80	AR
14	11:57	322 W Detroit St.	3.90	ME	12:32	2100 W New Orleans St.	3.60	ME
15	11:48	911 W. Elmira St.	3.00	T.R.	12:38	2700 N. 7th St.	3.40	T.R.
16	11:50	7213 S. Dennis Blvd.	3.60	R.M.	12:15	2909 E. Montpelier St.	3.20	R.M.
17	10:25	708 W. Waco St.	3.70	M.L.	13:51	7213 S. Dennis Blvd.	3.80	M.L.
18	11:21	322 W. Detroit	3.20	ML	1:28	13725 S. 124th St.	3.00	ML
19	09:36	1301 N. 53rd St.	3.40	M.L	15:01	3806 S. Orange Circle	3.10	M.L
20	8:57	1217 E Houston Ave.	3.40	ML	14:19	2305 W Vicksburg St.	3.60	ML
21	11:44	1200 E. Dover St.	3.70	S.B	12:11	2513 E. Dallas St.	3.70	S.B
22	11:28	8017 S. Peach Ave.	3.40	T.R.	12:13	2700 N. 7th St.	3.60	T.R.
23	10:23	1413 E. Pasadena St.	3.80	ML	12:22	12314 E. 126th Pl.	2.90	ML
24	9:05	4121 E. Omaha St.	3.00	ML	12:21	1116 W. Granger St.	3.00	ML
25	8:15	3706 S.Orange Cir.	2.80	ML	12:36	1817 S. Date Ave.	3.00	ML
26	9:04	2028 W. Broadway St.	3.60	ML	12:40	601 W. Los Angeles St.	3.80	ML
27	09:21	4209 W. Iola St.	3.20	M.L	12:10	1805 N. 11th St.	3.70	M.L
28	11:57	6575 369th Ave.	3.20	ME	12:52	2100 W New Orleans St.	3.40	ME

Average 3.37

Min. 2.80

Max. 3.90

Average 3.48

Min. 2.90

Max. 3.80