



REMARKS :	No data on the weather station for this day
	Influent flowmeter was down used the effluent flowmeter number for the Influent flow
	Operator run test but no issue with the pump and CL2 analyzer didn't pick it up. Not sure if we were out or just an error in the lab

I hereby certify the above to be correct to the best
of my knowledge.

Signed: 

Title: LLWRRF Manager