



To: City of Broken Arrow Drainage Advisory Committee
From: Patrick P. Wilson, P.E., CFM, Stormwater Division Manager
Project Name: Freeport & Cedar
Project Number: SW26130
DAC Case Number: 25-013
DAC Agenda Number: 25-1069
Allocated Funds: \$20,000.00
Basin: Haikey Creek
Funds Spent: \$214.50
Funds Remaining: \$19,785.50

Description:

The project is located at 319 W. Freeport St. in Old Town Broken Arrow at the southeast corner of W. Freeport St. and N. Cedar Ave.

Street runoff flows west along freeport St. and through the applicant's front yard and driveway. The runoff from the street has washed out the gravel driveway causing craters, inundates the backyard, and gets into the applicant's shed.

The ditch along the road appears to have silted in over time. Curb and gutter along Cedar St. appears to be blocking the flow, diverting the street runoff onto the applicant's property causing adverse impacts.

Staff requested and Council approved expenditure of \$20,000.00 of the 2018 General Obligation Bond Proposition 6 for mitigating the erosion and re-establishing the ditch along W. Freeport St.

The work was performed by the City's Streets and Stormwater team.

Recommendation: Close the project and transfer the remaining funds back to the Haikey Creek Basin fund.

Patrick P. Wilson 12/1/2025
Patrick P. Wilson, P.E. CFM
City of Broken Arrow
Stormwater Division Manager

Tara Kilpatrick 12/9/2025
Tara Kilpatrick
City of Broken Arrow
Budget Officer



Before





After

