

BROKEN ARROW PLANNING COMMISSION AND CITY COUNCIL SUBDIVISION PLAT REVIEW CHECKLIST

PLAT INFORMATION

NAME OF PLAT: Crossings at Lynn Lane

CASE NUMBER: PT15-117A

RELATED CASE NUMBERS: BAZ 1947, BAZ 1961, and PT15-117

COUNTY: Tulsa

SECTION/TOWNSHIP/RANGE: 13/T18N/R14E

GENERAL LOCATION: North and east of the northeast corner of Washington Street and 9th Street

CURRENT ZONING: A-1 (RS-3 via BAZ 1947 and BAZ 1961)

SANITARY SEWER BASIN: Lynn Lane

STORM WATER DRAINAGE BASIN: Broken Arrow Creek

ENGINEER: Crafton Tull
ENGINEER ADDRESS: 220 E. 8th Street
Tulsa, OK 74119
ENGINEER PHONE NUMBER: 918-584-0347

DEVELOPER: Rausch Coleman Homes
DEVELOPER ADDRESS: 3420 N. Plainview Avenue
Fayetteville, AR 72703
DEVELOPER PHONE NUMBER: 479-455-9090

PRELIMINARY PLAT

APPLICATION MADE: July 19, 2016

TOTAL ACREAGE: 87.28 acres

NUMBER OF LOTS: 244

TAC MEETING DATE: August 9, 2016

PLANNING COMMISSION MEETING DATE: August 11, 2016

COMMENTS:

1. _____ Change case number to PT15-117A. Since conditional final plats will be submitted in phases, the case numbers for the conditional final plats will be PT15-117A-1, etc.
2. _____ Reserve Area A for Crossings at Lynn Lane 1 needs to be screened back as was done with the area to the north.
3. _____ Identify the area to the west as Crossings at Lynn Lane 1.
4. _____ Identify the area to the north of Block 3 and north of Block 7 as unplatted.
5. _____ The line around the perimeter of the plat needs to be a heavier weight than the interior lot lines.
6. _____ The owner shown on Sheets 1-3 needs to match the owner listed on Sheet 4. Please revise accordingly.
7. _____ Covenants need to identify a mandatory homeowners association. The homeowners association shall own and maintain all the reserve areas. There shall be one overall homeowners association responsible for all reserves, landscaping, fences, etc. for all phases of Crossings at Lynn Lane. This shall be described in the covenants.
8. _____ Development around the oil wells and tank batteries shall meet all state and local requirements. No conditional final plat shall be submitted until written verification is provided confirming that the proposed development near the oil wells and tank batteries is in compliance with all state and local requirements. It appears that the wells will be closed prior to conditional final plat, however, if not, staff recommends access to active oil wells for maintenance purposes should be through a separate private access easement and not through public residential streets. If the Developer cannot have them closed prior to conditional final plat, the streets may have to be private with specific language in the covenants of the plat that would turn streets over to the City once the wells are closed. Any damage to the streets would be the responsibility of the Developer and/or homeowners association with repairs occurring before acceptance of the streets by the City.
9. _____ The pipe easement along the east property line should be placed outside the actual lot line for the lots along the east proposed boundary.
10. _____ Text overlap makes this plat difficult to read. Avoid text overlap with conditional final plat.
11. _____ Fence details shall be submitted with the landscape plan for the area adjacent to Washington Street. Fencing and landscaping shall be installed in accordance with the Zoning Ordinance. Maintenance of the fence and landscaping shall be the responsibility of the homeowners association and shall be so described in the covenants.
12. _____ Provide the certificate of authorization number for the engineer and surveyor.
13. _____ Reserve areas shall be identified consistently on all phases. For example, the reserve area in Crossings at Lynn Lane 1 is referenced as "Reserve Area A". The reserves areas in subsequent phases should be identified with a letter also.

14. _____ Label and identify building setback lines and easements, including showing distance information.
15. _____ As part of the phasing plan, there will need to be access to both 9th Street and Washington Street to meet the requirements of the Zoning Ordinance that all areas with more than twenty units have to have two points of access. A second point of access shall be provided with the next phase.
16. _____ Add to the covenants that the developer is responsible for constructing the sidewalk along both arterial streets and along the reserve areas adjacent to a street.
17. _____ Verify with utility companies that 17.5-foot utility easement through the tank battery is adequate and acceptable.
18. _____ Change “Registered” to “Licensed” in the Surveyor’s Certificate.
19. _____ On the location map, change “Crossings at Lynn Lane Phase 1” to “Crossings at Lynn Lane 1”.
20. _____ Add street names and addresses as assigned by the City of Broken Arrow.
21. _____ Add “minimum” to all building setback information contained in the Site Information table.
22. _____ Washington Street is a primary arterial street, which requires 60 feet of right-of-way from the section line. Show right-of-way dimension. In addition, show right-of-way to be dedicated by this plat, or if right-of-way has already been dedicated, show document number for dedication.
23. _____ Add abbreviations, such as “U/E” to the legend.
24. _____ Identify and label section line.
25. _____ Part of the information associated with private road easement and AEP/PSO easement has been left off the north boundary.
26. _____ Provide a 20-foot wide connection from Reserve Area 2 to the public street to the east. This 20-foot wide connection shall be a part of Reserve Area 2.
27. _____ Blocks 7 and 13 information is incomplete.
28. _____ Provide a 5-foot wide fence and landscape easement along Washington Street.
29. _____ Show the width of the right-of-way on all the interior streets.
30. _____ Add dimensions and bearings to all lots.
31. _____ Remove building setback lines from each lot and instead clarify where utility easement lines are located.
32. _____ Label Block 5.
33. _____ Provide written documentation, email is acceptable, that all lots meet the minimum frontage requirements of the RS-3 district. Some of the pie-shaped lots appear to have less than the required frontage.
34. _____ Show the width of the right-of-way at the street intersections with Washington Street. Right-of-way is required to be at least 70 feet in width.
35. _____ Remove the entire paragraph titled “Utility Easement Dedication” from the covenants.
36. _____ The overland drainage easements referenced in the covenants need to be shown on the plat.
37. _____ Fence and landscape plan for the area along Washington Street shall be submitted and approved prior to the plat being released for recording in Tulsa County.
38. _____ Identify the title of the owner who will be responsible for signing the plat.
39. _____ COBA design criteria manual 10.6.4 states, “Site grading shall provide surface water drainage directly into a storm sewer , natural drainage course, improved channel, or paved street without crossing more than four (4) adjacent lots.” Several areas, the junction of Blocks 6, 8, and 15 is one area where a storm sewer with an easement may be required to meet this requirement.

CONDITIONAL FINAL PLAT

NAME OF CONDITIONAL FINAL PLAT:

APPLICATION MADE:

TOTAL ACREAGE:

NUMBER OF LOTS:

TAC MEETING DATE:

PLANNING COMMISSION MEETING DATE:

CITY COUNCIL MEETING DATE:

COMMENTS:

40. _____
41. _____
42. _____
43. _____

CONDITIONS TO BE MET PRIOR TO FINAL RELEASE OF PLAT

LETTER OF APPROVAL FROM UTILITY COMPANY SUBMITTED?

- ___ NATURAL GAS COMPANY APPROVAL
- ___ ELECTRIC COMPANY APPROVAL
- ___ TELEPHONE COMPANY APPROVAL

- ___ CABLE COMPANY APPROVAL

CERTIFICATE OF RECORDS SEARCH FROM OKLAHOMA CORPORATION COMMISSION SUBMITTED?

- ___ OK CORPORATION COMMISSION CERTIFICATE OF RECORDS SEARCH
- ___ OKLAHOMA CORPORATION COMMISSION, CAROL COLLETT 405-521-2108

- ___ BUILDING PAD ELEVATIONS ON EACH LOT PLACED ON A COPY OF THE FINAL PLAT
- ___ MONUMENTS SHOWN ON PLAT
- ___ SLOPE ANALYSIS (1:4) FOR LOTS ADJACENT TO DRAINAGE CHANNELS APPROVED

DEVELOPMENT SERVICES/ENGINEERING APPROVAL

- ___ STORMWATER PLANS, APPROVED ON:
- ___ PAVING PLANS, APPROVED ON:
- ___ WATER PLANS, APPROVED ON:
- ___ SANITARY SEWER PLANS, APPROVED ON:
- ___ SEWAGE DISPOSAL PLANS, APPROVED BY DEPARTMENT OF ENVIRONMENTAL QUALITY ON:
- ___ WATER PLANS, APPROVED BY DEPARTMENT OF ENVIRONMENTAL QUALITY ON: _____
- ___ IS A SIDEWALK PERFORMANCE BOND DUE? _____ HAVE THEY BEEN SUBMITTED? _____
- ___ ARE PERFORMANCE BONDS OR ESCROW AGREEMENT DUE FOR WATER, STORM SEWERS, SANITARY SEWER AND PAVING? (CIRCLE APPLICABLE) _____ HAVE THEY BEEN SUBMITTED? _____
- ___ ENGINEERING DEPARTMENT/DEVELOPMENT SERVICES REVIEW COMPLETE ON: _____

PLANNING DEPARTMENT APPROVAL

- ___ ADDRESSES REVIEWED AND APPROVED
- ___ DETENTION DETERMINATION # ASSIGNED AND VERIFIED?
- ___ PLANNING DEPARTMENT REVIEW COMPLETE ON:
- ___ FINAL PLAT RECEIVED IN PLANNING DEPARTMENT AFTER UTILITY COMPANY SIGN OFF ON:
- ___ FINAL PLAT SENT TO ENGINEERING DEPARTMENT FOR FINAL REVIEW ON:

FEES

- | | |
|---|----------|
| ___ FINAL PLAT PROCESSING FEE | \$ _____ |
| ___ WATER LINE (S) UNDER PAYBACK CONTRACT | \$ _____ |
| ___ EXCESS SEWER CAPACITY FEE | \$ _____ |
| ___ ACCELERATION/DECELERATION LANES ESCROW | \$ _____ |
| ___ WATER LINE CONNECTIONS, PAYABLE TO CITY OR OTHERS | \$ _____ |
| ___ SEWER LINE CONNECTIONS, PAYABLE TO CITY OR OTHERS | \$ _____ |
| ___ STREET IMPROVEMENT (WIDENING) ASSESSMENTS | \$ _____ |
| ___ DRAINAGE SYSTEM IMPROVEMENTS PRO RATA COST | \$ _____ |
| ___ REIMBURSEMENT TO CITY OR OTHERS FOR WATER LINE CON. | \$ _____ |
| ___ REIMBURSEMENT TO CITY OR OTHERS FOR SEWER LINE CON. | \$ _____ |
| ___ STREET SIGNS, LIGHTS, ETC. | \$ _____ |
| ___ STORM WATER FEE-IN-LIEU OF DETENTION | \$ _____ |

TOTAL FEE(S) \$ _____

FINAL PROCESSING OF PLAT

____ DEVELOPMENT ENGINEER SUBMIT FINAL PLAT FOR MAYOR AND CITY CLERK SIGNATURE

____ FEES PAID ON: _____ IN THE AMOUNT OF: _____

____ DEVELOPMENT ENGINEER PICK UP FINAL PLAT FOR FILING

____ 11 COPIES OF FILED PLAT SUBMITTED TO PLANNING DEPARTMENT

____ PDF OF RECORDED PLAT SUBMITTED TO PLANNING DEPARTMENT