

City of Broken Arrow WTP Monthly Operational Report Summary
 Water Treatment Plant PWSID# OK 1021508

Reporting Period: [March] [2026]



Operating Data Summary

Water Production (MG)

	Month	Average Day
Raw Water Treated	322.32	10.4
Finished Water	310.51	10.0

Finished Water Turbidity:

	No. Samples	% of Total Samples
Greater than 0.5 NTU	0	0.00
Greater than 0.3 NTU	0	0.00
Greater than 0.1 NTU	0	0.00
Total No. of Turbidity Samples	186	
Highest Turbidity Reading	0.057	
No. Samples > 1 NTU	0	
No. Samples > 5 NTU	0	

Monthly Chemical Usage (Non-Membrane Usage)

Chemical	Total lbs	lbs/Finished MG
Sodium Hypochlorite	23,447	1,078.7
Salt (for hypo generation)	70,340	3,236.2
Liquid Ammonium Sulfate	2,944	9.0
Sodium Permanganate	1,812	3.0
Aluminum Chlorohydrate	78,789	45.4
Sodium Hydroxide	4,913	6.1
Hydrofluosilicic Acid	0	0.0

Monthly Costs

	Total	\$/Finished MG	\$/1000 gal
Plant Electricity	\$67,530.20	\$217.48	\$0.2175
Total Chemical	\$77,209.98	\$248.66	\$0.2487
Total Labor	\$119,469.87	\$384.76	\$0.3848
Services	\$33,259.51	\$107.11	\$0.1071
Materials and Supplies	\$5,174.64	\$16.67	\$0.0167
Equipment Expenses	\$2,034.65	\$6.55	\$0.0066
Total	\$304,678.85	\$981.23	\$0.9812

Total Chlorine Residual:

	No. Samples
Total Chlorine Residual <2.0 mg/L Leaving Plant	0

Individual Membrane Unit Turbidity Checklist

	YES/NO
1. IS TURBIDITY FROM EACH INDIVIDUAL MEMBRANE UNIT RECORDED EVERY 15 MINUTES?	YES
2. DID ANY SINGLE MEMBRANE UNIT EXCEED 2.0 NTU IN TWO CONSECUTIVE 15 MINUTE PERIODS? No, Go to Question 3. Yes, What date was the membrane profile completed? _____	NO
DID THIS SAME MEMBRANE UNIT EXCEED 2.0 NTU IN 2 CONSECUTIVE 15-MIN PERIODS DURING THE LAST MONTH? No, Go to Question 3. Yes, Schedule Comprehensive Performance Evaluation (CPE) with DEQ.	
3. DID ANY SINGLE MEMBRANE UNIT EXCEED 1.0 NTU IN TWO CONSECUTIVE 15 MINUTE PERIODS? No, Go to Question 4. Yes, What date was the filter profile completed? _____	NO
DID THIS SAME MEMBRANE UNIT FILTER EXCEED 1.0 NTU IN 2 CONSECUTIVE 15-MIN PERIODS DURING THE LAST 2 MONTHS? No, Go to Question 4. Yes, What date was the membrane self-assessment completed? _____	
4. DID ANY SINGLE MEMBRANE UNIT EXCEED 0.5 NTU IN 2 CONSECUTIVE 15-MIN PERIODS AT THE END OF 4 HRS OF OPERATION? No, You are finished with the checklist. Yes, What date was the membrane profile completed? _____	NO

* IF ANY OF QUESTIONS 2 THROUGH 4 ARE CHECKED "YES", YOU MUST COMPLETE THE TURBIDITY TRIGGER EVALUATION FORM AND ATTACH TO THIS MOR.

I hereby certify the above to be correct to the best of my knowledge:

Notes: Fluoride feed offline for tank inspection and feed system repairs.

Signed: Lou Ann Fisher 4/10/2026
Date

Title: Water Plant Manager

Operator Certificate No. 25369

Public Water System Name: COBA Water Treatment Plant
PWS ID No.: OK 1021508

Month: _____
Year _____

March
2026

Date	Water Production and Recycle Flows				
	Raw Water Pumped to Pre-Sed Basins (MG)	Raw Water Treated (MG)	Finished Water Delivered (MG)	Reverse Filtration Water Used (MG)	Lagoon Decant Water Pumped (MG)
1	10.52	10.10	9.48		0.42
2	0.00	9.87	9.46		0.75
3	7.55	10.32	9.44		0.52
4	21.60	8.71	8.95		0.51
5	7.06	9.31	8.27		0.51
6	0.00	7.85	8.00		0.50
7	0.00	8.48	8.33		0.53
8	0.14	8.50	8.60		0.52
9	21.10	10.31	9.48		0.57
10	9.48	9.14	8.83		0.56
11	0.00	9.61	8.41		0.58
12	0.00	8.00	8.23		0.53
13	0.00	9.01	9.07		0.53
14	0.11	10.05	9.22		0.58
15	11.02	9.58	9.08		0.55
16	11.01	9.00	8.70		0.43
17	11.01	8.70	8.53		0.44
18	11.00	9.09	9.29		0.70
19	10.99	11.28	10.84		0.23
20	10.99	10.72	11.03		0.20
21	11.00	11.62	11.64		0.29
22	11.14	12.44	11.67		0.30
23	21.36	12.18	11.53		0.44
24	21.25	11.98	11.26		0.89
25	21.24	11.75	11.95		0.81
26	21.08	12.39	12.21		0.69
27	16.89	12.89	11.92		0.65
28	10.94	11.67	10.67		0.63
29	10.94	12.12	11.84		0.61
30	10.95	12.59	12.79		0.61
31	17.09	13.09	11.80		0.61
TOTAL	317.46	322.32	310.51	0.00	16.67
AVG	10.24	10.40	10.02	#DIV/0!	0.54
MAX	21.60	13.09	12.79	0.00	0.89
MIN	0.00	7.85	8.00	0.00	0.20

Public Water System Name: COBA Water Treatment Plant
 PWS ID No.: OK 1021508

Month: March
 Year: 2026

TOTAL CHEMICAL COST:	\$77,210		
Cost Per MG Treated	\$239.55	Cost Per MG Delivered	\$248.66
Million Gallons Treated	322.32	Million Gallons Delivered	310.51

Non-Membrane System Chemical Usage

Date	Sodium Hypochlorite (CL) NaClO		Liquid Ammonium Sulfate (LAS)		Sodium Permanganate (SP)		Aluminum Chlorohydrate (ACH)		Sodium Hydroxide (SH)		Hydrofluosilicic Acid (HFS)	
	gal/day	lb/day	gal/day	lb/day	gal/day	lb/day	gal/day	lb/day	gal/day	lb/day	gal/day	lb/day
1	8,486	594.00	86.0	90.16	23.1	44.70	442	2467.37	17.1	44.55	0.0	0.00
2	8,021	561.46	81.0	84.84	0.0	0.00	411	2298.96	16.2	42.26	0.0	0.00
3	8,837	618.60	87.8	92.04	19.2	37.22	448	2501.22	17.4	45.25	0.0	0.00
4	8,210	574.70	76.6	80.26	47.6	92.17	385	2153.69	15.2	39.65	0.0	0.00
5	8,183	572.80	75.4	79.04	15.3	29.56	380	2122.75	15.1	39.47	0.0	0.00
6	8,002	560.14	73.7	77.21	0.0	0.00	369	2063.35	14.8	38.61	0.0	0.00
7	8,186	573.00	73.7	77.23	0.0	0.00	367	2050.76	14.7	38.43	0.0	0.00
8	8,590	601.31	78.3	82.09	0.0	0.04	392	2191.80	15.5	40.36	0.0	0.00
9	9,721	680.44	88.0	92.23	47.6	92.11	441	2461.90	21.0	54.65	0.0	0.00
10	9,166	641.59	78.1	81.81	22.5	43.58	387	2164.58	37.4	97.59	0.0	0.00
11	9,268	648.77	78.2	81.98	0.0	0.00	389	2172.75	43.0	112.14	0.0	0.00
12	9,225	645.75	75.7	79.38	0.0	0.00	378	2111.84	41.7	108.67	0.0	0.00
13	9,782	684.72	79.3	83.09	0.0	0.00	396	2213.57	43.4	113.07	0.0	0.00
14	10,605	742.32	87.1	91.23	0.0	0.00	437	2440.44	64.5	168.10	0.0	0.00
15	10,235	716.42	83.6	87.63	34.9	67.61	419	2339.83	74.9	195.12	0.0	0.00
16	9,740	681.79	78.9	82.68	35.0	67.69	392	2191.03	70.9	184.86	0.0	0.00
17	9,428	659.96	76.4	80.11	35.0	67.68	380	2125.69	68.6	178.76	0.0	0.00
18	10,086	706.01	80.0	83.88	34.9	67.61	401	2242.38	71.7	186.82	0.0	0.00
19	12,509	875.61	101.3	106.12	34.9	67.56	510	2847.46	90.3	235.32	0.0	0.00
20	11,855	829.86	95.2	99.81	34.9	67.52	479	2676.98	84.9	221.40	0.0	0.00
21	13,215	925.05	108.5	113.73	34.9	67.59	545	3043.03	96.6	251.77	0.0	0.00
22	12,946	906.21	107.0	112.12	35.0	67.70	538	3006.80	95.3	248.36	0.0	0.00
23	12,855	899.85	104.5	109.48	67.8	131.27	526	2941.02	93.2	242.77	0.0	0.00
24	12,624	883.69	102.3	107.23	67.5	130.58	513	2866.56	91.2	237.72	0.0	0.00
25	13,211	924.79	107.4	112.56	67.3	130.23	541	3020.28	95.7	249.45	0.0	0.00
26	13,287	930.12	108.9	114.15	66.9	129.51	546	3049.25	97.0	252.84	0.0	0.00
27	13,138	919.65	109.6	114.82	54.0	104.53	551	3077.39	97.6	254.49	0.0	0.00
28	11,655	815.86	96.2	100.77	34.7	67.23	484	2704.74	85.9	223.80	0.0	0.00
29	14,062	984.34	107.5	112.61	34.7	67.23	539	3009.89	95.7	249.50	0.0	0.00
30	15,339	1073.73	115.1	120.65	34.8	67.28	576	3218.62	102.4	266.94	0.0	0.00
31	14,487	1014.08	107.8	112.94	53.9	104.26	539	3012.93	96.0	250.10	0.0	0.00
TOTAL	334,952	23,447	2,809	2,944	937	1,812	14,100	78,789	1,885	4,913	0	0
AVG	10,805	756.34	91	94.96	30	58.47	455	2541.58	61	158.48	0	0.00
MAX	15,339	1073.73	115	120.65	68	131.27	576	3218.62	102	266.94	0	0.00
MIN	8,002	560.14	74	77.21	0	0.00	367	2050.76	15	38.43	0	0.00
COST	\$7,596.70		\$5,144.66		\$8,428.04		\$54,364.32		\$1,676.26		\$0.00	
\$/MG	\$23.57		\$15.96		\$26.15		\$168.67		\$5.20		\$0.00	

Public Water System Name: COBA Water Treatment Plant
PWS ID No.: OK 1021508

Month: March
Year: 2026

Date	pH (by Continuous Reading Analyzers)				Hardness and Alkalinity - Finished Water Grab Samples						
	Membrane Filtrate		Finished Water		Hardness (ppm)		Alkalinity (ppm as CaCO ₃)				CaCO ₃ Stability
	Daily Max	Daily Min	Daily Max	Daily Min	AM	PM	Phenol AM	Phenol PM	Total AM	Total PM	
1	7.8	7.8	8.0	7.9	201.00	201.00	0.00	0.00	134.00	132.00	5.00
2	7.8	7.8	8.0	7.9	204.00	202.00	0.00	0.00	133.00	135.00	7.00
3	7.8	7.8	7.9	7.9	208.00	200.00	0.00	0.00	136.00	140.00	11.00
4	7.8	7.7	7.9	7.9	206.00	197.00	0.00	0.00	136.00	131.00	11.00
5	7.7	7.7	7.9	7.8	204.00	201.00	0.00	0.00	135.00	133.00	8.00
6	7.7	7.6	7.8	7.8	206.00	210.00	0.00	0.00	138.00	132.00	6.00
7	7.6	7.5	7.8	7.8	203.00	205.00	0.00	0.00	136.00	134.00	5.00
8	7.5	7.4	7.8	7.8	203.00	204.00	0.00	0.00	136.00	132.00	4.00
9	7.6	7.4	7.8	7.8	209.00	196.00	0.00	0.00	134.00	132.00	4.00
10	7.7	7.4	7.9	7.8	202.00	200.00	0.00	0.00	133.00	137.00	10.00
11	7.5	7.4	7.9	7.9	206.00	191.00	0.00	0.00	137.00	137.00	3.00
12	7.4	7.3	7.9	7.9	199.00	193.00	0.00	0.00	133.00	131.00	4.00
13	7.3	7.2	7.9	7.9	206.00	200.00	0.00	0.00	136.00	131.00	2.00
14	7.2	7.2	7.9	7.9	200.00	206.00	0.00	0.00	133.00	134.00	10.00
15	7.3	7.2	8.0	7.9	195.00	197.00	0.00	0.00	133.00	132.00	8.00
16	7.2	7.2	8.1	8.0	191.00	193.00	0.00	0.00	130.00	130.00	4.00
17	7.2	7.1	8.1	8.1	193.00	195.00	0.00	0.00	128.00	128.00	8.00
18	7.1	7.1	8.1	8.0	189.00	202.00	0.00	0.00	127.00	130.00	3.00
19	7.1	7.1	8.1	8.0	196.00	192.00	0.00	0.00	128.00	128.00	3.00
20	7.1	7.1	8.0	8.0	191.00	207.00	0.00	0.00	130.00	129.00	7.00
21	7.6	7.1	8.0	7.9	192.00	185.00	0.00	0.00	125.00	124.00	5.00
22	7.6	7.5	7.9	7.9	187.00	186.00	0.00	0.00	125.00	122.00	4.00
23	7.6	7.5	8.0	7.9	190.00	181.00	0.00	0.00	124.00	127.00	5.00
24	7.6	7.6	8.0	8.0	187.00	182.00	0.00	0.00	125.00	124.00	4.00
25	7.6	7.5	8.0	8.0	188.00	180.00	0.00	0.00	127.00	130.00	2.00
26	7.6	7.5	8.0	8.0	188.00	178.00	0.00	0.00	133.00	122.00	10.00
27	7.6	7.5	8.0	8.0	185.00	193.00	0.00	0.00	124.00	123.00	1.00
28	7.6	7.5	8.1	8.0	183.00	184.00	0.00	0.00	125.00	120.00	9.00
29	7.5	7.4	8.1	8.0	184.00	182.00	0.00	0.00	125.00	126.00	7.00
30	7.4	7.4	8.1	8.1	192.00	180.00	0.00	0.00	126.00	127.00	6.00
31	7.4	7.3	8.1	8.1	181.00	185.00	0.00	0.00	128.00	125.00	3.00
AVG					196	194	0	0	131	130	6
MAX	7.8	7.8	8.1	8.1	209	210	0	0	138	140	11
MIN	7.1	7.1	7.8	7.8	181	178	0	0	124	120	1

Public Water System Name: COBA Water Treatment Plant
 PWS ID No.: OK 1021508

Month: March
 Year: 2026

Date	Turbidity (NTU) Continuous Reading Analyzers						Chlorine Residual (Total or Free as Noted, mg/L) Continuous Reading Analyzers					
	Finished Water (Highest Reading in 4-hour Period)						Finished Water Total Chlorine (Min. in 4 Hour Period)					
	12:00 AM	4:00 AM	8:00 AM	12:00 PM	4:00 PM	8:00 PM	12:00 AM	4:00 AM	8:00 AM	12:00 PM	4:00 PM	8:00 PM
1	0.03	0.02	0.02	0.02	0.02	0.02	3.48	3.42	3.46	3.51	3.50	3.46
2	0.02	0.02	0.02	0.02	0.02	0.02	3.43	3.51	3.51	3.50	3.48	3.45
3	0.02	0.02	0.02	0.02	0.03	0.02	3.41	3.42	3.44	3.46	3.45	3.44
4	0.02	0.02	0.02	0.02	0.02	0.02	3.56	3.41	3.40	3.44	3.51	3.53
5	0.02	0.02	0.02	0.03	0.02	0.02	3.45	3.58	3.58	3.58	3.55	3.51
6	0.02	0.03	0.02	0.02	0.02	0.02	3.36	3.41	3.42	3.43	3.42	3.39
7	0.02	0.02	0.02	0.02	0.02	0.02	3.48	3.38	3.40	3.45	3.50	3.50
8	0.02	0.02	0.02	0.02	0.02	0.02	3.47	3.46	3.45	3.44	3.44	3.46
9	0.03	0.02	0.02	0.03	0.02	0.02	3.42	3.49	3.49	3.49	3.49	3.44
10	0.02	0.02	0.02	0.02	0.02	0.02	3.42	3.40	3.40	3.42	3.43	3.43
11	0.02	0.02	0.03	0.02	0.02	0.02	3.42	3.38	3.43	3.43	3.43	3.43
12	0.02	0.02	0.03	0.02	0.02	0.02	3.52	3.42	3.42	3.43	3.45	3.50
13	0.02	0.02	0.02	0.03	0.03	0.02	3.48	3.53	3.53	3.51	3.47	3.48
14	0.03	0.02	0.02	0.02	0.03	0.03	3.45	3.51	3.48	3.52	3.52	3.48
15	0.02	0.02	0.02	0.02	0.02	0.03	3.48	3.46	3.46	3.49	3.47	3.48
16	0.03	0.02	0.02	0.03	0.02	0.03	3.48	3.50	3.50	3.50	3.49	3.48
17	0.02	0.03	0.02	0.02	0.02	0.02	3.49	3.48	3.48	3.48	3.49	3.46
18	0.02	0.02	0.02	0.02	0.02	0.02	3.56	3.50	3.49	3.48	3.50	3.52
19	0.02	0.02	0.02	0.03	0.02	0.02	3.66	3.59	3.63	3.65	3.67	3.67
20	0.02	0.03	0.03	0.03	0.03	0.03	3.61	3.68	3.69	3.65	3.62	3.57
21	0.02	0.02	0.03	0.02	0.02	0.02	3.51	3.62	3.62	3.60	3.55	3.54
22	0.02	0.03	0.02	0.02	0.03	0.03	3.39	3.48	3.48	3.44	3.41	3.39
23	0.03	0.02	0.03	0.03	0.03	0.03	3.60	3.42	3.54	3.59	3.59	3.61
24	0.02	0.02	0.02	0.02	0.04	0.02	3.57	3.52	3.60	3.59	3.58	3.58
25	0.03	0.04	0.03	0.03	0.03	0.02	3.58	3.58	3.59	3.55	3.62	3.63
26	0.02	0.02	0.03	0.03	0.02	0.03	3.52	3.58	3.60	3.60	3.55	3.53
27	0.04	0.05	0.03	0.04	0.03	0.03	3.58	3.52	3.53	3.55	3.58	3.56
28	0.03	0.03	0.03	0.02	0.03	0.03	3.61	3.58	3.56	3.56	3.56	3.57
29	0.02	0.03	0.03	0.03	0.03	0.04	3.68	3.63	3.60	3.62	3.64	3.66
30	0.03	0.05	0.03	0.03	0.02	0.03	3.70	3.71	3.73	3.73	3.73	3.72
31	0.04	0.03	0.03	0.02	0.06	0.03	3.58	3.62	3.70	3.68	3.62	3.59
AVG	0.02	0.03	0.02	0.02	0.03	0.02	3.5	3.5	3.5	3.5	3.5	3.5
MAX	0.04	0.05	0.03	0.04	0.06	0.04	3.7	3.7	3.7	3.7	3.7	3.7
MIN	0.02	0.02	0.02	0.02	0.02	0.02	3.4	3.4	3.4	3.4	3.4	3.4

Finished Water Turbidity Summary and Statistics

	No. of Samples	Percent of Total Samples
Turbidity Greater Than 0.5 NTU	0	0
Turbidity Greater Than 0.3 NTU	0	0
Turbidity Greater Than 0.1 NTU	0	0

Total Number of Turbidity Samples | 186

PWSID 1021508

SYSTEM COBA WTP

MONTH March

*Type of Material Applied

Hydrofluosilicic Acid

YEAR 2026

Date	Water Treated 1,000s of Gallons	APPLIED		RESIDUAL F, ppm (RAW)		RESIDUAL F, ppm (FINISHED WATER)	
		LBS/DAY	PPM of F	AM	PM	AM	PM
1	9,481	0	0.00	0.31	0.43	0.25	0.21
2	9,455	0	0.00	0.46	0.27	0.12	0.09
3	9,435	0	0.00	0.20	0.38	0.22	0.37
4	8,954	0	0.00	0.33	0.41	0.23	0.38
5	8,266	0	0.00	0.29	0.29	0.20	0.39
6	8,000	0	0.00	0.32	0.55	0.18	0.58
7	8,330	0	0.00	0.30	0.39	0.16	0.24
8	8,598	0	0.00	0.31	0.47	0.19	0.23
9	9,479	0	0.00	0.34	0.51	0.18	0.18
10	8,825	0	0.00	0.18	0.39	0.10	0.16
11	8,413	0	0.00	0.26	0.28	0.11	0.55
12	8,232	0	0.00	0.33	0.22	0.18	0.04
13	9,075	0	0.00	0.31	0.34	0.23	0.23
14	9,221	0	0.00	0.29	0.61	0.20	0.47
15	9,083	0	0.00	0.34	0.28	0.19	0.17
16	8,703	0	0.00	0.31	0.32	0.13	0.23
17	8,528	0	0.00	0.24	0.20	0.07	0.19
18	9,285	0	0.00	0.41	0.52	0.23	0.40
19	10,840	0	0.00	0.30	0.25	0.21	0.26
20	11,028	0	0.00	0.21	0.50	0.14	0.34
21	11,638	0	0.00	0.20	0.18	0.20	0.25
22	11,673	0	0.00	0.26	0.19	0.15	0.18
23	11,530	0	0.00	0.06	0.17	0.12	0.00
24	11,260	0	0.00	0.04	0.31	0.12	0.18
25	11,948	0	0.00	0.17	0.28	0.05	0.04
26	12,207	0	0.00	0.26	0.28	0.02	0.27
27	11,917	0	0.00	0.27	0.40	0.14	0.14
28	10,675	0	0.00	0.27	0.57	0.17	0.43
29	11,838	0	0.00	0.29	0.36	0.21	0.22
30	12,788	0	0.00	0.33	0.25	0.25	0.05
31	11,804	0	0.00	0.11	0.44	0.09	0.23
Total	310,507	0					
Avg.	10,016	0	0.00	0.27	0.36	0.16	0.25

*Example: Sodium Fluoride, Sodium Fluorosilicate (Sodium Silicofluoride), and Fluorosilicic Acid (Hydrofluosilicic Acid)

It is required that this report be received by the 10th of the following month.

SEND TO: OSDH-Dental Health Services AND

Dept of Environmental Quality

1000 N.E. Tenth Street

PO Box 1677

Oklahoma City, OK 73117-1299

Oklahoma City, OK 73101-1677

I hereby certify the above to be

correct to the best of my knowledge.

Signed Lou Ann Fisher

Title: Water Plant Manager

City Broken Arrow

ODH Form No. 561 / DEQ Form 631-001

Notes: Fluoride feed offline for tank inspection and feed system repairs.

Public Water System Name: COBA Water Treatment Plant

Month: March

PWS ID No.: OK 1021508

Year: 2026

Date	Distribution Total Chlorine mg/L A.M. Sample				Distribution Total Chlorine mg/L P.M. Sample			
	Time	Location	mg/L	Sampler	Time	Location	mg/L	Sampler
1	10:34	35600 E. 66th St. S.	3.60	T.R.	17:18	6057 S. 353rd E. Ave.	3.40	T.R.
2	09:21	2513 E. Dallas St.	3.30	M.L.	13:21	5005 S. Lions Ave.	3.40	M.L.
3	9:46	4608 W Eagle Pass St.	3.20	ML	12:47	1903 W. Rockport Pl.	3.80	ML
4	10:07	7301 S. Nyssa Ave.	3.10	ML	1:25	1217 E. Houston St.	3.30	ML
5	09:03	7213 S. Dennis Blvd.	3.70	M.L.	12:49	1005 N. Willow Ave.	3.40	M.L.
6	9:20	4205 E Omaha St.	3.60	ML	13:25	905 S Narcissus Ave.	3.50	ML
7	0812	6057 S 353rd E Ave	3.20	ME	15:16	36500 E 66th St. S.	3.30	ME
8	11:43	2909 E. Montpelier St.	3.30	R.M.	12:36	1903 W. Rockport Pl.	3.20	R.M.
9	9.08	515 W. Quapah Pl	3.20	ML	12:41	7213 S. Dennis Blvd.	3.50	ML
10	8:27	13725 S. 124th E. Ave.	3.00	ML	12:09	5005 S. Lions Ave.	3.30	ML
11	9:02	2909 E Montpelier St.	3.20	ML	12:12	702 E. Mason Dr.	3.50	ML
12	9:42	1909 S. Gardenia Ave.	2.70	ML	1:45	4117 S. Elm Ave.	3.00	ML
13	8:12	2613 N 10th Street E.	3.30	AR	12:02	2408 W Yuma St.	3.20	AR
14	11:47	322 W Detroit St.	3.10	ME	12:20	4705 S Elm Pl.	3.30	ME
15	11:38	2700 N. 7th St.	3.60	T.R.	12:37	1105 W. Nashville St.	3.50	T.R.
16	10:09	322 W. Detroit St.	2.60	M.L.	13:56	2909 E. Montpelier St.	3.00	M.L.
17	10:14	12314 E. 126th Pl.	2.70	M.L.	14:00	1903 W. Rockport Pl.	2.90	M.L.
18	09:16	3706 S. Orange Cir.	2.40	M.L.	13:51	605 S. Elder Ave.	2.50	M.L.
19	8:12	4909 S Oak Ave.	3.30	AR	12:09	2505 E Omaha St.	3.30	AR
20	08:50	4417 W. Vandalia St.	3.10	M.L.	12:38	301 W. New Orleans St.	3.90	M.L.
21	11:41	2513 E. Dallas St.	3.70	S.B	12:13	702 E. Mason Dr.	3.70	S.B
22	06:00	6575 369th E. Ave.	3.60	J.B.	16:12	36500 E. 66th St. S.	3.40	T.R.
23	8:34	109 E. Juneau St.	2.90	AR	12:27	2907 W. Washington Pl.	3.10	AR
24	8:30	1821 S. Willow Ave.	2.90	AR	1:20	2509 E. Dallas St.	3.00	AR
25	9:51	4608 W. Eagle Pass St.	3.10	ML	12:03	804 N. 1st St.	2.90	ML
26	8:23	2101 W. Gary St.	3.20	ML	12:00	608 E. Pensacola St.	3.20	ML
27	09:12	1701 S. Van Buren Ct.	3.40	M.L.	14:44	2221 W. Memphis Pl.	3.10	M.L.
28	11:41	2513 E Dallas St.	3.70	ME	12:10	4755 S Aspen Ave.	3.30	ME
29	11:44	2909 E. Montpelier St.	3.60	R.M.	13:09	1903 W. Rockport Pl.	3.40	R.M.
30	10:38	2313 S. Elder Ave.	3.20	ML	12:42	2500 E. Oakland St.	3.40	ML
31	09:34	600 W. Madison St.	3.50	M.L.	14:25	4800 S. Brich Ave.	3.50	M.L.

Average 3.23

Average 3.30

Min. 2.40

Min. 2.50

Max. 3.70

Max. 3.90