

City of Broken Arrow WTP Monthly Operational Report Summary
Water Treatment Plant PWSID# OK 1021508

Reporting Period: [June] [2026]



Operating Data Summary

Water Production (MG)

	Month	Average Day
Raw Water Treated	378.37	12.6
Finished Water	354.59	11.8

Monthly Chemical Usage (Non-Membrane Usage)

Chemical	Total lbs	lbs/Finished MG
Sodium Hypochlorite	29,998	1,208.5
Salt (for hypo generation)	89,994	3,625.6
Liquid Ammonium Sulfate	3,626	9.8
Sodium Permanganate	1,457	2.1
Aluminum Chlorohydrate	97,934	49.4
Sodium Hydroxide	10,043	10.9
Hydrofluosilicic Acid	0	0.0

Total Chlorine Residual:

	No. Samples
Total Chlorine Residual <2.0 mg/L Leaving Plant	0

Finished Water Turbidity:

	No. Samples	% of Total Samples
Greater than 0.5 NTU	0	0.00
Greater than 0.3 NTU	0	0.00
Greater than 0.1 NTU	0	0.00
Total No. of Turbidity Samples	180	
Highest Turbidity Reading	0.092	
No. Samples > 1 NTU	0	
No. Samples > 5 NTU	0	

Monthly Costs

	Total	\$/Finished MG	\$/1000 gal
Plant Electricity	\$19,258.37	\$54.31	\$0.0543
Total Chemical	\$110,909.55	\$312.78	\$0.3128
Total Labor	\$188,469.11	\$531.51	\$0.5315
Services	\$23,609.39	\$66.58	\$0.0666
Materials and Supplies	\$103,234.49	\$291.13	\$0.2911
Equipment Expenses	\$7,400.73	\$20.87	\$0.0209
Total	\$452,881.64	\$1,277.18	\$1.2772

Individual Membrane Unit Turbidity Checklist

1. IS TURBIDITY FROM EACH INDIVIDUAL MEMBRANE UNIT RECORDED EVERY 15 MINUTES?	YES/NO
	YES
2. DID ANY SINGLE MEMBRANE UNIT EXCEED 2.0 NTU IN TWO CONSECUTIVE 15 MINUTE PERIODS?	NO
No, Go to Question 3.	
Yes, What date was the membrane profile completed?	
DID THIS SAME MEMBRANE UNIT EXCEED 2.0 NTU IN 2 CONSECUTIVE 15-MIN PERIODS DURING THE LAST MONTH?	
No, Go to Question 3.	
Yes, Schedule Comprehensive Performance Evaluation (CPE) with DEQ.	
3. DID ANY SINGLE MEMBRANE UNIT EXCEED 1.0 NTU IN TWO CONSECUTIVE 15 MINUTE PERIODS?	NO
No, Go to Question 4.	
Yes, What date was the filter profile completed?	
DID THIS SAME MEMBRANE UNIT FILTER EXCEED 1.0 NTU IN 2 CONSECUTIVE 15-MIN PERIODS DURING THE LAST 2 MONTHS?	
No, Go to Question 4.	
Yes, What date was the membrane self-assessment completed?	
4. DID ANY SINGLE MEMBRANE UNIT EXCEED 0.5 NTU IN 2 CONSECUTIVE 15-MIN PERIODS AT THE END OF 4 HRS OF OPERATION?	NO
No, You are finished with the checklist.	
Yes, What date was the membrane profile completed?	

* IF ANY OF QUESTIONS 2 THROUGH 4 ARE CHECKED "YES", YOU MUST COMPLETE THE TURBIDITY TRIGGER EVALUATION FORM AND ATTACH TO THIS MOR.

I hereby certify the above to be correct to the best of my knowledge:

Notes: Fluoride feed offline for repairs to the bulk tank.

Signed: RouAnn Fisher 7/10/2026
Date

Title: Water Plant Manager

Operator Certificate No. 25369

Date	Water Production and Recycle Flows				
	Raw Water Pumped to Pre-Sed Basins (MG)	Raw Water Treated (MG)	Finished Water Delivered (MG)	Reverse Filtration Water Used (MG)	Lagoon Decant Water Pumped (MG)
1	10.93	14.71	13.99		0.80
2	10.93	13.68	11.65		0.83
3	10.97	11.02	10.51		0.47
4	10.96	12.05	11.80		0.71
5	10.96	11.49	11.66		0.70
6	10.95	11.87	11.00		0.76
7	10.93	10.61	9.91		0.77
8	10.92	11.91	11.53		0.51
9	10.94	12.36	12.24		0.63
10	10.95	13.23	12.91		0.63
11	10.96	13.33	12.77		0.73
12	10.96	12.86	12.51		0.67
13	10.97	12.84	12.18		0.67
14	10.97	12.60	10.55		0.86
15	15.29	12.08	12.03		0.54
16	26.05	12.55	12.42		0.76
17	13.11	13.86	13.08		0.68
18	10.79	13.09	12.54		0.66
19	10.79	12.94	12.62		0.63
20	10.80	13.26	13.43		0.68
21	10.73	14.74	13.11		0.71
22	10.11	14.84	10.91		0.98
23	10.76	15.36	10.46		0.69
24	10.71	10.33	10.27		0.69
25	3.75	10.51	10.08		0.67
26	0.00	10.45	10.23		0.64
27	0.00	10.70	10.34		0.85
28	10.77	11.54	11.49		0.48
29	16.70	13.48	13.12		0.66
30	24.14	14.07	13.25		0.66
31					
TOTAL	337.83	378.37	354.59	0.00	20.72
AVG	11.26	12.61	11.82	#DIV/0!	0.69
MAX	26.05	15.36	13.99	0.00	0.98
MIN	0.00	10.33	9.91	0.00	0.47

TOTAL CHEMICAL COST: \$110,910

Cost Per MG Treated \$293.13

Cost Per MG Delivered \$312.78

Million Gallons Treated 378.37

Million Gallons Delivered 354.59

Non-Membrane System Chemical Usage

Date	Sodium Hypochlorite (CL) NaClO		Liquid Ammonium Sulfate (LAS)		Sodium Permanganate (SP)		Aluminum Chlorohydrate (ACH)		Sodium Hydroxide (SH)		Hydrofluosilicic Acid (HFS)	
	gal/day	lb/day	gal/day	lb/day	gal/day	lb/day	gal/day	lb/day	gal/day	lb/day	gal/day	lb/day
1	17,337	1213.59	138.9	145.57	24.8	47.96	666	3723.68	3.3	8.51	0.0	0.00
2	14,198	993.88	115.3	120.82	24.8	47.97	564	3154.06	3.5	9.15	0.0	0.00
3	13,200	923.99	105.1	110.10	24.9	48.14	515	2875.06	35.0	91.16	0.0	0.00
4	13,801	966.04	112.9	118.36	24.9	48.13	555	3103.72	92.5	241.02	0.0	0.00
5	13,944	976.06	115.8	121.40	24.9	48.11	568	3175.05	94.8	246.99	0.0	0.00
6	13,362	935.36	110.5	115.83	24.9	48.08	540	3015.92	90.5	235.88	0.0	0.00
7	12,492	874.47	100.0	104.79	24.8	47.99	488	2728.23	88.0	229.42	0.0	0.00
8	14,310	1001.70	114.6	120.14	24.8	47.93	565	3158.80	133.2	347.11	0.0	0.00
9	15,114	1057.95	121.5	127.37	24.6	47.65	600	3352.10	169.9	442.75	0.0	0.00
10	14,811	1036.76	121.9	127.73	24.8	48.07	611	3414.00	172.4	449.19	0.0	0.00
11	14,987	1049.11	126.1	132.17	24.9	48.12	635	3547.66	164.7	429.19	0.0	0.00
12	14,865	1040.54	124.0	129.93	24.9	48.11	626	3497.17	144.0	375.29	0.0	0.00
13	14,254	997.77	117.2	122.83	24.9	48.17	598	3340.87	137.7	358.92	0.0	0.00
14	12,614	882.95	100.6	105.43	24.9	48.14	515	2876.81	119.3	310.93	0.0	0.00
15	14,165	991.56	114.4	119.86	34.4	66.59	593	3312.89	136.7	356.20	0.0	0.00
16	14,316	1002.13	117.4	123.04	59.1	114.39	614	3433.67	140.8	366.97	0.0	0.00
17	15,281	1069.70	122.6	128.50	30.0	58.07	639	3568.18	147.0	382.99	0.0	0.00
18	14,750	1032.50	117.7	123.35	24.5	47.38	609	3401.69	141.5	368.77	0.0	0.00
19	14,627	1023.89	117.0	122.63	24.5	47.38	603	3369.11	141.0	367.35	0.0	0.00
20	15,111	1057.80	124.9	130.88	24.5	47.42	645	3603.19	159.5	415.62	0.0	0.00
21	15,173	1062.10	126.1	132.13	24.3	47.11	651	3640.40	173.0	450.91	0.0	0.00
22	15,173	1062.10	126.1	132.13	24.3	47.11	651	3640.40	173.0	450.91	0.0	0.00
23	18,150	1270.47	145.9	152.92	32.7	63.29	752	4200.25	199.3	519.42	0.0	0.00
24	12,460	872.18	96.5	101.11	24.4	47.18	496	2771.95	132.6	345.57	0.0	0.00
25	12,566	879.59	96.7	101.33	22.4	43.29	495	2766.38	132.9	346.42	0.0	0.00
26	12,104	847.30	93.2	97.71	0.0	0.01	479	2678.61	128.2	334.19	0.0	0.00
27	12,761	893.28	98.3	103.02	0.0	0.04	505	2820.09	135.1	352.15	0.0	0.00
28	12,532	877.21	96.4	101.07	10.5	20.22	495	2767.11	132.6	345.61	0.0	0.00
29	15,378	1076.48	122.1	127.99	24.9	48.10	632	3533.63	167.3	435.99	0.0	0.00
30	14,706	1029.44	120.0	125.75	44.8	86.75	620	3463.47	164.4	428.50	0.0	0.00
31												
TOTAL	428,542	29,998	3,460	3,626	753	1,457	17,526	97,934	3,853	10,043	0	0
AVG	14,285	999.93	115	120.86	25	48.56	584	3264.47	128	334.77	0	0.00
MAX	18,150	1270.47	146	152.92	59	114.39	752	4200.25	199	519.42	0	0.00
MIN	12,104	847.30	93	97.71	0	0.01	479	2678.61	3	8.51	0	0.00
COST	\$16,901.27		\$6,266.10		\$10,752.08		\$68,553.91		\$8,436.18		\$0.01	
\$/MG	\$44.67		\$16.56		\$28.42		\$181.18		\$22.30		\$0.00	

Public Water System Name: COBA Water Treatment Plant
PWS ID No.: OK 1021508

Month: June
Year: 2026

Date	pH (by Continuous Reading Analyzers)				Hardness and Alkalinity - Finished Water Grab Samples						
	Membrane Filtrate		Finished Water		Hardness (ppm)		Alkalinity (ppm as CaCO ₃)				CaCO ₃ Stability
	Daily Max	Daily Min	Daily Max	Daily Min	AM	PM	Phenol AM	Phenol PM	Total AM	Total PM	
1	7.6	7.6	7.7	7.6	154.00	154.00	0.00	0.00	104.00	104.00	0.00
2	7.7	7.6	7.7	7.6	152.00	150.00	0.00	0.00	107.00	102.00	-4.00
3	7.6	7.5	7.7	7.7	150.00	149.00	0.00	0.00	100.00	102.00	-6.00
4	7.6	7.5	7.9	7.7	145.00	149.00	0.00	0.00	104.00	100.00	-6.00
5	7.6	7.6	8.0	7.9	159.00	146.00	0.00	0.00	104.00	101.00	1.00
6	7.6	7.6	8.0	7.9	149.00	146.00	0.00	0.00	104.00	99.00	2.00
7	7.7	7.6	8.1	8.0	153.00	143.00	0.00	0.00	104.00	98.00	4.00
8	7.7	7.7	8.2	8.1	146.00	138.00	0.00	0.00	99.00	97.00	1.00
9	7.7	7.7	8.4	8.2	150.00	137.00	0.00	0.00	105.00	99.00	4.00
10	7.7	7.7	8.4	8.4	142.00	133.00	0.00	0.00	98.00	96.00	3.00
11	7.8	7.7	8.5	8.4	138.00	134.00	0.00	0.00	99.00	98.00	1.00
12	7.7	7.7	8.4	8.3	138.00	156.00	0.00	0.00	99.00	95.00	5.00
13	7.7	7.6	8.4	8.3	137.00	135.00	0.00	0.00	96.00	92.00	3.00
14	7.8	7.7	8.4	8.3	134.00	129.00	0.00	0.00	95.00	94.00	3.00
15	7.8	7.7	8.4	8.4	130.00	132.00	0.00	0.00	92.00	94.00	6.00
16	7.8	7.7	8.4	8.3	132.00	129.00	0.00	0.00	92.00	93.00	6.00
17	7.7	7.6	8.3	8.2	131.00	127.00	0.00	0.00	93.00	92.00	-1.00
18	7.7	6.7	8.4	8.0	129.00	130.00	0.00	0.00	91.00	92.00	2.00
19	7.5	7.4	8.0	7.9	146.00	130.00	0.00	0.00	100.00	92.00	5.00
20	7.5	7.4	8.0	7.8	133.00	134.00	0.00	0.00	94.00	91.00	2.00
21	7.4	7.4	8.0	7.9	137.00	131.00	0.00	0.00	101.00	96.00	4.00
22	7.4	7.4	8.0	7.9	135.00	132.00	0.00	0.00	94.00	94.00	6.00
23	7.5	7.4	8.0	7.9	130.00	131.00	0.00	0.00	92.00	93.00	4.00
24	7.4	7.4	7.9	7.9	132.00	132.00	0.00	0.00	93.00	93.00	7.00
25	7.4	7.4	7.9	7.8	131.00	128.00	0.00	0.00	95.00	89.00	5.00
26	7.4	7.4	7.9	7.8	130.00	135.00	0.00	0.00	100.00	90.00	3.00
27	7.4	7.4	7.9	7.9	132.00	129.00	0.00	0.00	92.00	90.00	5.00
28	7.5	7.4	7.9	7.9	130.00	125.00	0.00	0.60	94.00	91.00	2.00
29	7.5	7.4	8.0	7.9	120.00	127.00	0.00	0.00	93.00	92.00	5.00
30	7.5	7.4	8.1	8.0	127.00	127.00	0.00	0.00	91.00	93.00	1.00
31											
AVG					138	136	0	0	98	95	2
MAX	7.8	7.7	8.5	8.4	159	156	0	1	107	104	7
MIN	7.4	6.7	7.7	7.6	120	125	0	0	91	89	-6

Date	Turbidity (NTU) Continuous Reading Analyzers						Chlorine Residual (Total or Free as Noted, mg/L) Continuous Reading Analyzers					
	Finished Water (Highest Reading in 4-hour Period)						Finished Water Total Chlorine (Min. in 4 Hour Period)					
	12:00 AM	4:00 AM	8:00 AM	12:00 PM	4:00 PM	8:00 PM	12:00 AM	4:00 AM	8:00 AM	12:00 PM	4:00 PM	8:00 PM
1	0.02	0.02	0.02	0.02	0.02	0.02	3.70	3.81	3.77	3.73	3.61	3.59
2	0.02	0.02	0.02	0.02	0.02	0.02	3.50	3.81	3.79	3.61	3.53	3.49
3	0.05	0.02	0.02	0.02	0.04	0.04	3.57	3.64	3.63	3.63	3.60	3.46
4	0.02	0.05	0.02	0.02	0.02	0.02	3.59	3.63	3.68	3.70	3.68	3.59
5	0.02	0.02	0.03	0.03	0.02	0.02	3.73	3.66	3.70	3.74	3.75	3.71
6	0.02	0.02	0.02	0.04	0.02	0.02	3.83	3.83	3.81	3.85	3.87	3.86
7	0.03	0.02	0.02	0.02	0.02	0.02	3.84	3.82	3.83	3.83	3.84	3.84
8	0.02	0.02	0.02	0.02	0.02	0.03	3.82	3.88	3.87	3.90	3.90	3.83
9	0.02	0.02	0.02	0.02	0.09	0.02	3.92	3.85	4.00	3.99	3.95	3.91
10	0.02	0.02	0.02	0.02	0.02	0.02	3.87	3.98	3.94	3.91	3.90	3.85
11	0.02	0.02	0.02	0.02	0.02	0.02	3.87	3.89	3.92	3.90	3.89	3.86
12	0.02	0.02	0.02	0.02	0.02	0.02	3.88	3.89	3.92	3.90	3.89	3.89
13	0.02	0.02	0.09	0.08	0.02	0.02	3.74	3.86	3.78	3.79	3.80	3.73
14	0.02	0.02	0.02	0.02	0.02	0.02	3.87	3.81	3.82	3.86	3.86	3.87
15	0.02	0.02	0.02	0.02	0.02	0.02	3.90	3.79	3.91	3.94	3.95	3.81
16	0.02	0.02	0.02	0.03	0.03	0.02	3.83	3.86	3.81	3.80	3.77	3.75
17	0.02	0.02	0.02	0.02	0.02	0.02	3.73	3.83	3.80	3.79	3.79	3.72
18	0.02	0.02	0.02	0.03	0.03	0.02	3.93	3.78	3.88	3.89	3.88	3.90
19	0.02	0.02	0.02	0.02	0.02	0.02	3.97	3.95	3.97	3.96	3.96	3.96
20	0.02	0.02	0.02	0.02	0.02	0.02	3.95	3.97	3.92	3.90	3.95	3.96
21	0.02	0.03	0.08	0.02	0.02	0.02	3.73	3.92	3.91	3.87	3.62	3.75
22	0.02	0.03	0.08	0.02	0.02	0.02	3.75	3.77	3.81	3.78	3.75	3.72
23	0.02	0.04	0.07	0.02	0.03	0.02	3.77	3.79	3.77	3.76	3.77	3.75
24	0.02	0.02	0.02	0.02	0.02	0.02	3.78	3.79	3.80	3.80	3.79	3.78
25	0.02	0.02	0.02	0.02	0.02	0.02	3.72	3.74	3.79	3.78	3.75	3.74
26	0.02	0.03	0.02	0.02	0.02	0.03	3.71	3.70	3.72	3.73	3.72	3.68
27	0.02	0.02	0.02	0.02	0.02	0.02	3.95	3.76	4.03	4.04	3.97	3.95
28	0.03	0.02	0.02	0.03	0.03	0.02	4.04	4.10	4.09	4.07	4.02	4.00
29	0.02	0.02	0.02	0.03	0.02	0.02	4.06	4.18	4.17	4.14	4.08	4.05
30	0.02	0.02	0.02	0.03	0.02	0.02	4.15	4.10	4.16	4.13	4.11	4.10
31												
AVG	0.02	0.02	0.03	0.03	0.03	0.02	3.8	3.8	3.9	3.9	3.8	3.8
MAX	0.05	0.05	0.09	0.08	0.09	0.04	4.1	4.2	4.2	4.1	4.1	4.1
MIN	0.02	0.02	0.02	0.02	0.02	0.02	3.5	3.6	3.6	3.6	3.5	3.5

Finished Water Turbidity Summary and Statistics

	No. of Samples	Percent of Total Samples
Turbidity Greater Than 0.5 NTU	0	0
Turbidity Greater Than 0.3 NTU	0	0
Turbidity Greater Than 0.1 NTU	0	0

Total Number of Turbidity Samples	180
-----------------------------------	-----

Date	Water Treated 1,000s of Gallons	APPLIED		RESIDUAL F, ppm (RAW)		RESIDUAL F, ppm (FINISHED WATER)	
		LBS/DAY	PPM of F	AM	PM	AM	PM
1	13,992	0	0.00	0.17	0.24	0.00	0.05
2	11,653	0	0.00	0.01	0.12	0.09	0.00
3	10,505	0	0.00	0.30	0.20	0.04	0.11
4	11,798	0	0.00	0.25	0.18	0.18	0.06
5	11,664	0	0.00	0.16	0.12	0.04	0.10
6	11,001	0	0.00	0.22	0.23	0.00	0.13
7	9,906	0	0.00	0.21	0.20	0.03	0.01
8	11,534	0	0.00	0.42	0.17	0.24	0.00
9	12,241	0	0.00	0.15	0.13	0.00	0.07
10	12,913	0	0.00	0.43	0.08	0.27	0.00
11	12,768	0	0.00	0.22	0.26	0.09	0.15
12	12,507	0	0.00	0.21	0.43	0.05	0.34
13	12,181	0	0.00	0.23	0.13	0.10	0.07
14	10,548	0	0.00	0.22	0.06	0.06	0.00
15	12,027	0	0.00	0.31	0.25	0.11	0.10
16	12,425	0	0.00	0.26	0.26	0.11	0.10
17	13,076	0	0.00	0.15	0.04	0.00	0.00
18	12,543	0	0.00	0.05	0.24	0.08	0.01
19	12,624	0	0.00	0.21	0.29	0.00	0.00
20	13,435	0	0.00	0.23	0.43	0.07	0.19
21	13,110	0	0.00	0.24	0.19	0.18	0.05
22	10,910	0	0.00	0.24	0.54	0.01	0.06
23	10,456	0	0.00	0.18	0.23	0.00	0.04
24	10,267	0	0.00	0.19	0.43	0.00	0.35
25	10,081	0	0.00	0.19	0.27	0.12	0.21
26	10,227	0	0.00	0.21	0.43	0.00	0.33
27	10,340	0	0.00	0.20	0.02	0.00	0.00
28	11,487	0	0.00	0.06	0.19	0.01	0.07
29	13,124	0	0.00	0.04	0.10	0.00	0.00
30	13,250	0	0.00	0.05	0.22	0.00	0.06
31							
Total	354,594	0					
Avg.	11,820	0	0.00	0.20	0.22	0.06	0.09

*Example: Sodium Fluoride, Sodium Fluorosilicate (Sodium Silicofluoride), and

Fluorosilicic Acid (Hydrofluosilicic Acid)

It is required that this report be received by the 10th of the following month.

SEND TO: OSDH-Dental Health Services AND

Dept of Environmental Quality

1000 N.E. Tenth Street

PO Box 1677

Oklahoma City, OK 73117-1299

Oklahoma City, OK 73101-1677

I hereby certify the above to be

correct to the best of my knowledge.

Signed *Paul Ann Gisher*

Title: Water Plant Manager

City Broken Arrow

ODH Form No. 561 / DEQ Form 631-001

Notes: Fluoride feed offline for repairs to the bulk tank.

Date	Distribution Total Chlorine mg/L A.M. Sample				Distribution Total Chlorine mg/L P.M. Sample			
	Time	Location	mg/L	Sampler	Time	Location	mg/L	Sampler
1	9:36	601 N. Palm Ave.	3.00	ML	1:02	702 E.Mason Dr.	3.00	ML
2	7:50	8017 S. Peach Ave.	2.90	ML	12:43	7900 E. Norman St.	3.00	ML
3	8:57	4608 W. Eagle Pass St.	2.20	ML	12:11	2513 E. Dallas St.	3.20	ML
4	10:27	708 W. Waco St.	2.80	M.L.	13:07	1301 N. 53rd St.	3.70	M.L.
5	7:50	2907 W Washington Pl.	2.50	ML	13:10	700 E Wichita St.	3.30	ML
6	8:14	36500 E 66th St S.	4.00	ME	13:42	6057 S 353rd E Ave.	3.80	ME
7	11:45	2909 E. Montpelier St.	3.40	R.M.	13:53	1116 W. Granger St.	3.00	R.M.
8	10:54	1817 S.Date Ave.	2.80	ML	12:09	13725 S. 124th E. Ave.	2.50	ML
9	8:02	4121 E. Omaha St.	2.90	ML	12:22	3706 S. Orange Cir.	2.50	ML
10	7:53	608 E. Pensacola St.	3.00	M.L.	12:24	605 S. Elder Ave.	2.30	M.L.
11	9:21	613 E. Fargo St.	3.70	ML	12:10	1611 W. Durham Ct.	3.80	ML
12	07:58	3800 W. Twin Oaks St.	2.80	M.L	12:58	523 E. Detroit St.	2.70	M.L
13	11:38	1116 W. Granger St.	3.40	S.B	12:22	2513 E. Dallas St.	3.40	S.B
14	11:37	1116 W. Granger St.	3.20	T.R.	12:32	2700 N. 7th St.	3.70	T.R.
15	10:52	3412 W. Charlotte St.	3.20	M.L.	12:18	1200 E. Dover St.	3.60	M.L.
16	08:29	4608 W. Eagle Pass St.	2.70	M.L.	12:12	2513 E. Dallas St.	3.50	M.L.
17	06:58	7213 S. Dennis Blvd.	3.70	M.L.	12:21	1729 S. Pine Ave.	3.30	M.L.
18	08:47	1116 W. Granger St.	3.20	M.L.	12:11	702 E. Mason Dr.	3.30	M.L.
19	08:19	4407 S. Olive Ave	2.00	M.L	12:49	605 S. Elder Ave	2.60	M.L
20	11:41	3707 N Ironwood Pl.	3.70	ME	12:30	3621 S Elm Pl.	3.50	ME
21	11:43	2909 E. Montpelier St.	3.80	R.M.	13:47	5005 S. Lions Ave.	3.80	R.M.
22	10:46	1903 W. Rockport Pl.	3.20	M.L.	12:37	322 W. Detroit St.	2.70	M.L.
23	08:04	605 S. Elder Ave.	2.00	M.L.	12:22	4121 E. Omaha St.	3.20	M.L.
24	08:24	2909 E. Montpelier St.	3.30	M.L.	12:00	12314 E. 126th Pl.	2.80	M.L.
25	10:23	713 W. Norman St.	2.90	M.L.	13:55	1501 S. Willow Ave.	2.60	M.L.
26	7:43	608 E Pensacola St.	2.10	ML	13:00	709 W Southpark Blvd.	3.10	ML
27	11:39	708 W. Juneau St.	3.40	S.B	12:10	1301 N. 53rd St.	3.40	S.B
28	11:43	1116 W. Granger St.	3.60	T.R.	12:38	2700 N. 7th St.	3.70	T.R.
29	09:31	708 W. Waco St.	3.30	M.L.	12:06	1116 W. Granger St.	3.10	M.L.
30	08:31	6705 S. Oak Ave.	3.50	M.L.	14:05	1817 S. Willow Ave.	2.40	M.L.

Average 3.07

Min. 2.00

Max. 4.00

Average 3.15

Min. 2.30

Max. 3.80