City of Broken Arrow WTP Monthly Operational Report Summary

Water Treatment Plant PWSID# OK 1021508

Reporting Period: [June] [2025]

CITY OF BROKEN ARROW
Where opportunity lives

Operating Data Summary

Water Production (MG)

	Month	Average Day
Raw Water Treated	389.22	13.0
Finished Water	372.84	12.4

Monthly Chemical Usage (Non-Membrane Usage)

Chemical	Total lbs	lbs/Finished MG
Sodium Hypochlorite	30,854	1,182.2
Salt (for hypo generation)	92,561	3,546.5
Liquid Ammonium Sulfate	3,766	9.6
Sodium Permanganate	2,132	3.0
Aluminum Chlorohydrate	101,672	48.8
Sodium Hydroxide	12,951	13.3
Hydrofluosilisic Acid	0	0.0

Total Chlorine Residual:

	No. Samples
Total Chlorine Residual <2.0 mg/L Leaving Plant	0

Finished Water Turbidity:

	No. Samples	% of Total Samples
Greater than 0.5 NTU	0	0.00
Greater than 0.3 NTU	0	0.00
Greater than 0.1 NTU	0	0.00
Total No. of Turbidity Samples	180	
Highest Turbidity Reading	0.092	
No. Samples > 1 NTU	0	
No. Samples > 5 NTU	0	

Monthly Costs

	Total	$/Finished MG	$/1000 gal
Plant Electricity	$80,392.23	$215.62	$0.2156
Total Chemical	$121,261.76	$325.24	$0.3252
Total Labor	$114,705.03	$307.65	$0.3077
Services	$77,597.61	$208.12	$0.2081
Materials and Supplies	$27,434.42	$73.58	$0.0736
Equipment Expenses	$16,814.18	$45.10	$0.0451
Total	$438,205.23	$1,175.31	$1.1753

Individual Membrane Unit Turbidity Checklist

	YES/NO
1. IS TURBIDITY FROM EACH INDIVIDUAL MEMBRANE UNIT RECORDED EVERY 15 MINUTES?	YES
2. DID ANY SINGLE MEMBRANE UNIT EXCEED 2.0 NTU IN TWO CONSECUTIVE 15 MINUTE PERIODS?	NO
No, Go to Question 3.	
Yes, What date was the membrane profile completed? _____	
DID THIS SAME MEMBRANE UNIT EXCEED 2.0 NTU IN 2 CONSECUTIVE 15-MIN PERIODS DURING THE LAST MONTH?	
No, Go to Question 3.	
Yes, Schedule Comprehensive Performance Evaluation (CPE) with DEQ.	
3. DID ANY SINGLE MEMBRANE UNIT EXCEED 1.0 NTU IN TWO CONSECUTIVE 15 MINUTE PERIODS?	NO
No, Go to Question 4.	
Yes, What date was the filter profile completed? _____	
DID THIS SAME MEMBRANE UNIT FILTER EXCEED 1.0 NTU IN 2 CONSECUTIVE 15-MIN PERIODS DURING THE LAST 2 MONTHS?	
No, Go to Question 4.	
Yes, What date was the membrane self-assessment completed? _____	
4. DID ANY SINGLE MEMBRANE UNIT EXCEED 0.5 NTU IN 2 CONSECUTIVE 15-MIN PERIODS AT THE END OF 4 HRS OF OPERATION?	NO
No, You are finished with the checklist.	
Yes, What date was the membrane profile completed? _____	

*** IF ANY OF QUESTIONS 2 THROUGH 4 ARE CHECKED "YES", YOU MUST COMPLETE THE TURBIDITY TRIGGER EVALUATION FORM AND ATTACH TO THIS MOR.**

I hereby certify the above to be correct to the best of my knowledge:

Signed: Lou Ann Fisher **7/10/2025** (Date)

Title: Water Plant Manager

Operator Certificate No. 25369

Notes: 1: Fluoride feed down for repairs.
2: Memebrane Filtrate pH on the 27th: SCADA recorded invalid numbers due to power outage from lightning.

Public Water System Name: COBA Water Treatment Plant Month: June
PWS ID No.: OK 1021508 Year 2025

Date	Water Production and Recycle Flows				
	Raw Water Pumped to Pre-Sed Basins (MG)	Raw Water Treated (MG)	Finished Water Delivered (MG)	Reverse Filtration Water Used (MG)	Lagoon Decant Water Pumped (MG)
1	10.80	12.83	11.64		0.70
2	10.50	13.87	13.58		0.69
3	19.40	13.64	11.96		0.70
4	28.30	11.80	10.79		0.69
5	9.40	11.26	11.47		0.52
6	10.50	10.87	10.55		0.60
7	8.50	10.19	10.13		0.59
8	9.50	13.33	11.35		0.59
9	9.80	11.64	11.82		0.77
10	9.90	12.22	12.52		0.74
11	9.86	11.92	11.71		0.63
12	10.00	11.43	9.92		0.65
13	10.03	10.32	10.97		0.78
14	9.95	11.81	10.13		0.79
15	9.80	10.26	10.08		1.09
16	9.66	11.34	11.20		0.69
17	9.77	11.72	10.60		0.61
18	9.80	10.85	10.81		0.65
19	9.84	12.33	11.38		0.48
20	9.91	13.38	14.33		0.75
21	12.17	13.21	12.85		1.06
22	20.20	13.47	12.79		0.74
23	20.15	15.68	15.63		0.64
24	20.14	16.32	15.53		0.63
25	20.10	18.13	18.99		0.63
26	20.10	17.97	16.30		0.63
27	1.72	17.71	16.15		0.64
28	10.85	14.51	12.21		0.80
29	10.86	11.75	12.75		0.93
30	10.87	13.46	12.70		1.11
31					
TOTAL	**372.36**	**389.22**	**372.84**	**0.00**	**21.50**
AVG	12.41	12.97	12.43	#DIV/0!	0.72
MAX	28.30	18.13	18.99	0.00	1.11
MIN	1.72	10.19	9.92	0.00	0.48

Public Water System Name: COBA Water Treatment Plant
PWS ID No.: OK 1021508

Month: June
Year: 2025

TOTAL CHEMICAL COST:	$121,262		
Cost Per MG Treated	$311.55	Cost Per MG Delivered	$325.24
Million Gallons Treated	389.22	Million Gallons Delivered	372.84

Non-Membrane System Chemical Usage

Date	Sodium Hypochlorite (CL) NaClO		Liquid Ammonium Sulfate (LAS)		Sodium Permanganate (SP)		Aluminum Chlorohydrate (ACH)		Sodium Hydroxide (SH)		Hydrofluosilisic Acid (HFS)	
	gal/day	lb/day	gal/day	lb/day	gal/day	lb/day	gal/day	lb/day	gal/day	lb/day	gal/day	lb/day
1	12,908	903.55	106.8	111.98	24.3	47.00	555	3102.61	124.0	323.07	0.0	0.00
2	15,727	1100.87	130.5	136.74	27.3	52.75	683	3817.67	179.2	467.14	0.0	0.00
3	13,580	950.63	112.1	117.50	48.1	93.06	586	3274.12	161.2	420.25	0.0	0.00
4	12,822	897.57	100.6	105.39	82.6	159.80	528	2950.03	144.8	377.37	0.0	0.00
5	15,280	1069.60	107.2	112.31	34.1	65.94	558	3118.80	154.2	401.90	0.0	0.00
6	14,543	1018.01	97.8	102.48	34.0	65.80	506	2826.94	140.9	367.17	0.0	0.00
7	13,086	915.99	93.4	97.93	34.0	65.80	484	2702.00	134.7	351.06	0.0	0.00
8	13,596	951.70	107.0	112.14	34.0	65.80	564	3150.65	153.1	399.13	0.0	0.00
9	14,048	983.34	111.7	117.06	34.0	65.81	577	3222.86	159.3	415.22	0.0	0.00
10	15,185	1062.92	119.7	125.46	34.0	65.81	614	3432.07	170.6	444.60	0.0	0.00
11	13,505	945.36	107.5	112.61	32.8	63.38	553	3088.23	153.4	399.70	0.0	0.00
12	12,053	843.74	95.9	100.52	34.7	67.13	491	2743.84	137.1	357.33	0.0	0.00
13	13,062	914.37	104.3	109.29	36.4	70.40	536	2995.10	148.9	387.95	0.0	0.00
14	11,842	828.91	94.0	98.53	36.1	69.91	486	2714.29	134.4	350.33	0.0	0.00
15	12,151	850.54	98.7	103.49	35.6	68.85	501	2799.06	140.8	366.99	0.0	0.00
16	12,523	876.62	103.9	108.92	35.0	67.81	528	2950.34	147.2	383.59	0.0	0.00
17	12,551	878.59	104.2	109.23	35.4	68.58	529	2955.78	147.5	384.50	0.0	0.00
18	12,105	847.35	99.9	104.73	35.6	68.80	506	2828.97	141.6	369.07	0.0	0.00
19	13,637	954.58	112.7	118.08	35.7	69.11	576	3219.28	159.5	415.61	0.0	0.00
20	16,607	1162.49	134.8	141.26	36.0	69.61	688	3842.81	190.2	495.63	0.0	0.00
21	14,963	1047.43	121.5	127.30	43.8	84.68	621	3469.69	171.6	447.22	0.0	0.00
22	15,213	1064.88	123.5	129.41	73.3	141.86	631	3524.00	175.8	458.24	0.0	0.00
23	18,386	1287.04	152.3	159.61	73.2	141.55	768	4291.43	217.9	567.93	0.0	0.00
24	17,960	1257.21	155.1	162.51	73.1	141.48	765	4276.04	216.9	565.21	0.0	0.00
25	21,912	1533.86	190.7	199.83	73.0	141.27	926	5174.53	261.4	681.37	0.0	0.00
26	18,663	1306.41	162.7	170.52	26.0	50.37	788	4405.91	223.3	582.07	0.0	0.00
27	18,237	1276.60	165.6	173.51	0.0	0.07	803	4484.28	226.0	589.02	0.0	0.00
28	13,974	978.15	120.7	126.47	0.0	0.00	587	3280.06	162.9	424.57	0.0	0.00
29	14,997	1049.77	126.8	132.92	0.0	0.00	616	3442.61	142.6	371.73	0.0	0.00
30	15,651	1095.57	131.7	138.06	0.0	0.00	642	3588.22	148.1	386.09	0.0	0.00
31												
TOTAL	440,766	30,854	3,593	3,766	1,102	2,132	18,195	101,672	4,969	12,951	0	0
AVG	14,692	1028.46	120	125.53	37	71.08	607	3389.07	166	431.70	0	0.00
MAX	21,912	1533.86	191	199.83	83	159.80	926	5174.53	261	681.37	0	0.00
MIN	11,842	828.91	93	97.93	0	0.00	484	2702.00	124	323.07	0	0.00
COST	$16,966.89		$6,507.88		$15,737.35		$71,170.55		$10,878.89		$0.20	
$/MG	$43.59		$16.72		$40.43		$182.85		$27.95		$0.00	

Public Water System Name: COBA Water Treatment Plant
PWS ID No.: OK 1021508

Month: June
Year: 2025

Date	pH (by Continuous Reading Analyzers)				Hardness and Alkalinity - Finished Water Grab Samples						
					Hardness (ppm)		Alkalinity (ppm as $CaCO_3$)				$CaCO_3$ Stability
	Membrane Filtrate		Finished Water				Phenol	Phenol	Total	Total	
	Daily Max	Daily Min	Daily Max	Daily Min	AM	PM	AM	PM	AM	PM	
1	7.7	7.7	8.1	8.0	154.00	158.00	0.00	0.00	100.00	100.00	4.00
2	7.7	7.7	8.1	8.1	155.00	158.00	0.00	0.00	99.00	103.00	1.00
3	7.7	7.6	8.1	8.1	158.00	160.00	0.00	0.00	106.00	109.00	1.00
4	7.7	7.7	8.2	8.1	159.00	158.00	0.00	0.00	104.00	114.00	6.00
5	7.7	7.7	8.2	8.2	159.00	158.00	0.00	0.00	102.00	101.00	6.00
6	7.7	7.7	8.3	8.2	156.00	157.00	0.00	0.00	102.00	102.00	0.00
7	7.7	7.7	8.3	8.2	154.00	162.00	0.00	0.00	102.00	101.00	1.00
8	7.7	7.6	8.2	8.1	154.00	155.00	0.00	0.00	100.00	100.00	5.00
9	7.7	7.7	8.2	8.1	156.00	158.00	0.00	0.00	101.00	101.00	1.00
10	7.7	7.6	8.1	8.1	157.00	151.00	0.00	0.00	103.00	104.00	1.00
11	7.7	7.6	8.1	8.0	157.00	154.00	0.00	0.00	102.00	99.00	1.00
12	7.7	7.6	8.0	8.0	150.00	153.00	0.00	0.00	101.00	101.00	1.00
13	7.7	7.6	8.1	8.0	150.00	152.00	0.00	0.00	98.00	100.00	-3.00
14	7.7	7.6	8.2	8.1	150.00	150.00	0.00	0.00	94.00	97.00	2.00
15	7.8	7.7	8.3	8.2	148.00	149.00	0.00	0.00	101.00	96.00	2.00
16	7.7	7.7	8.3	8.2	147.00	142.00	0.00	0.00	95.00	93.00	1.00
17	7.7	7.6	8.2	8.2	153.00	136.00	0.00	0.00	97.00	91.00	3.00
18	7.8	7.7	8.4	8.2	138.00	158.00	0.00	0.00	93.00	93.00	-2.00
19	8.4	7.6	8.4	8.3	141.00	136.00	0.00	0.00	95.00	95.00	3.00
20	7.8	7.7	8.3	8.2	132.00	134.00	0.00	0.00	90.00	92.00	-2.00
21	7.7	7.6	8.2	8.1	122.00	133.00	0.00	0.00	86.00	89.00	3.00
22	7.7	7.6	8.2	8.1	125.00	131.00	0.00	0.00	90.00	92.00	-3.00
23	7.8	7.6	8.4	8.2	127.00	128.00	0.00	0.00	91.00	90.00	2.00
24	7.7	7.4	8.4	8.2	130.00	127.00	0.00	0.00	90.00	90.00	4.00
25	7.7	7.6	8.2	8.2	129.00	129.00	0.00	0.00	91.00	90.00	3.00
26	7.7	7.6	8.2	8.1	126.00	130.00	0.00	0.00	87.00	90.00	1.00
27	14.0	0.0	9.1	4.0	126.00	128.00	0.00	0.00	90.00	90.00	0.00
28	7.8	7.7	8.4	8.2	127.00	130.00	0.00	0.00	91.00	91.00	-2.00
29	7.8	7.7	8.4	8.2	128.00	127.00	0.00	0.00	92.00	90.00	1.00
30	7.8	7.7	8.3	8.2	129.00	122.00	0.00	0.00	92.00	89.00	4.00
31											
AVG					**143**	**144**	**0**	**0**	**96**	**96**	**2**
MAX	14.0	7.7	9.1	8.3	159	162	0	0	106	114	6
MIN	7.7	0.0	8.0	4.0	122	122	0	0	86	89	-3

Public Water System Name: COBA Water Treatment Plant
PWS ID No.: OK 1021508

Month: June
Year: 2025

Date	Turbidity (NTU) Continuous Reading Analyzers						Chlorine Residual (Total or Free as Noted, mg/L) Continuous Reading Analyzers					
	Finished Water (Highest Reading in 4-hour Period)						Finished Water Total Chlorine (Min. in 4 Hour Period)					
	12:00 AM	4:00 AM	8:00 AM	12:00 PM	4:00 PM	8:00 PM	12:00 AM	4:00 AM	8:00 AM	12:00 PM	4:00 PM	8:00 PM
1	0.02	0.02	0.03	0.02	0.02	0.02	3.50	3.56	3.51	3.47	3.42	3.41
2	0.03	0.02	0.02	0.02	0.02	0.02	3.64	3.61	3.63	3.62	3.61	3.61
3	0.02	0.02	0.02	0.02	0.04	0.03	3.47	3.63	3.61	3.58	3.54	3.50
4	0.02	0.02	0.03	0.03	0.02	0.02	3.41	3.46	3.48	3.44	3.42	3.46
5	0.04	0.02	0.02	0.03	0.02	0.03	3.46	3.39	3.41	3.44	3.44	3.46
6	0.02	0.02	0.02	0.03	0.03	0.02	3.49	3.63	3.62	3.59	3.52	3.48
7	0.02	0.02	0.03	0.02	0.03	0.02	3.48	3.63	3.62	3.52	3.52	3.47
8	0.02	0.03	0.02	0.03	0.04	0.02	3.60	3.55	3.56	3.56	3.46	3.45
9	0.02	0.02	0.03	0.02	0.02	0.02	3.62	3.62	3.64	3.61	3.55	3.54
10	0.03	0.02	0.04	0.02	0.03	0.03	3.68	3.64	3.64	3.67	3.63	3.60
11	0.03	0.03	0.03	0.03	0.02	0.04	3.57	3.67	3.61	3.57	3.55	3.55
12	0.03	0.03	0.03	0.03	0.03	0.04	3.50	3.61	3.60	3.57	3.53	3.53
13	0.02	0.03	0.03	0.03	0.03	0.03	3.56	3.52	3.54	3.59	3.60	3.55
14	0.02	0.05	0.06	0.03	0.04	0.03	3.48	3.67	3.62	3.63	3.62	3.50
15	0.03	0.03	0.03	0.03	0.03	0.03	3.62	3.54	3.56	3.63	3.63	3.63
16	0.04	0.06	0.03	0.03	0.03	0.04	3.60	3.61	3.60	3.61	3.59	3.58
17	0.05	0.09	0.03	0.07	0.03	0.04	3.51	3.63	3.63	3.60	3.59	3.51
18	0.03	0.04	0.03	0.06	0.04	0.04	3.72	3.57	3.69	3.69	3.68	3.72
19	0.02	0.05	0.05	0.06	0.03	0.02	3.73	3.68	3.71	3.72	3.73	3.73
20	0.03	0.02	0.03	0.02	0.03	0.02	3.81	3.73	3.76	3.75	3.74	3.75
21	0.02	0.02	0.02	0.03	0.02	0.02	3.69	3.78	3.74	3.70	3.67	3.64
22	0.02	0.02	0.03	0.02	0.02	0.02	3.70	3.72	3.71	3.72	3.68	3.64
23	0.02	0.02	0.02	0.02	0.02	0.02	3.91	3.78	3.83	3.85	3.87	3.85
24	0.03	0.02	0.03	0.02	0.02	0.02	3.86	3.89	3.86	3.86	3.85	3.87
25	0.02	0.02	0.03	0.03	0.02	0.02	4.07	3.92	3.93	3.93	3.98	4.04
26	0.03	0.02	0.02	0.02	0.02	0.02	3.95	3.96	3.86	3.81	3.80	3.85
27	0.02	0.02	0.02	0.02	0.02	0.02	3.81	3.97	3.96	3.95	3.94	3.81
28	0.02	0.02	0.02	0.02	0.02	0.02	3.80	3.80	3.79	3.79	3.79	3.79
29	0.02	0.02	0.02	0.02	0.03	0.02	3.78	3.78	3.78	3.77	3.78	3.73
30	0.02	0.02	0.03	0.02	0.02	0.02	3.82	3.78	3.78	3.83	3.84	3.84
31												
AVG	**0.03**	**0.03**	**0.03**	**0.03**	**0.03**	**0.03**	**3.7**	**3.7**	**3.7**	**3.7**	**3.7**	**3.6**
MAX	0.05	0.09	0.06	0.07	0.04	0.04	4.1	4.0	4.0	3.9	4.0	4.0
MIN	0.02	0.02	0.02	0.02	0.02	0.02	3.4	3.4	3.4	3.4	3.4	3.4

Finished Water Turbidity Summary and Statistics

	No. of Samples	Percent of Total Samples
Turbidity Greater Than 0.5 NTU	0	0
Turbidity Greater Than 0.3 NTU	0	0
Turbidity Greater Than 0.1 NTU	0	0

Total Number of Turbidity Samples	180

PWSID 1021508 SYSTEM COBA WTP MONTH June

*Type of Material Applied **Hydrofluosilicic Acid** YEAR 2025

Date	Water Treated	APPLIED		RESIDUAL F, ppm (RAW)		RESIDUAL F, ppm (FINISHED WATER)	
	1,000s of Gallons	LBS/DAY	PPM of F	AM	PM	AM	PM
1	11,640	0	0.00	0.44	0.24	0.37	0.17
2	13,575	0	0.00	0.15	0.26	0.09	0.14
3	11,962	0	0.00	0.16	0.29	0.18	0.20
4	10,792	0	0.00	0.28	0.26	0.29	0.23
5	11,471	0	0.00	0.25	0.24	0.19	0.20
6	10,554	0	0.00	0.46	0.37	0.41	0.37
7	10,128	0	0.00	0.25	0.15	0.22	0.22
8	11,354	0	0.00	0.36	0.30	0.27	0.30
9	11,823	0	0.00	0.16	0.28	0.32	0.17
10	12,521	0	0.00	0.24	0.21	0.21	0.26
11	11,711	0	0.00	0.23	0.33	0.22	0.24
12	9,920	0	0.00	0.38	0.34	0.37	0.23
13	10,965	0	0.00	0.43	0.21	0.41	0.18
14	10,128	0	0.00	0.30	0.30	0.21	0.24
15	10,081	0	0.00	0.28	0.27	0.26	0.22
16	11,201	0	0.00	0.24	0.20	0.43	0.14
17	10,604	0	0.00	0.26	0.12	0.25	0.22
18	10,812	0	0.00	0.05	0.08	0.11	0.16
19	11,376	0	0.00	0.18	0.23	0.21	0.17
20	14,327	0	0.00	0.20	0.21	0.23	0.20
21	12,846	0	0.00	0.17	0.08	0.21	0.03
22	12,790	0	0.00	0.28	0.19	0.26	0.18
23	15,631	0	0.00	0.08	0.14	0.01	0.14
24	15,534	0	0.00	0.19	0.16	0.18	0.16
25	18,988	0	0.00	0.06	0.23	0.11	0.17
26	16,295	0	0.00	0.45	0.21	0.41	0.09
27	16,145	0	0.00	0.23	0.20	0.16	0.07
28	12,211	0	0.00	0.36	0.19	0.22	0.08
29	12,753	0	0.00	0.12	0.31	0.02	0.19
30	12,704	0	0.00	0.09	0.12	0.04	0.04
31							
Total	372,842	0					
Avg.	12,428	0	0.00	0.24	0.22	0.23	0.18

*Example: Sodium Fluoride, Sodium Fluorosilicate (Sodium Silicofluoride), and Fluorosilicic Acid (Hydrofluosilicic Acid)

It is required that this report be received by the 10th of the following month.

SEND TO: OSDH-Dental Health Services AND
1000 N.E. Tenth Street
Oklahoma City, OK 73117-1299

Dept of Environmental Quality
PO Box 1677
Oklahoma City, OK 73101-1677

I hereby certify the above to be correct to the best of my knowledge.

Signed LaDonna Fisher

Title: Water Plant Manager

City **Broken Arrow**

ODH Form No. 561 / DEQ Form 631-001

Notes: Fluoride feed down for repairs.

Public Water System Name: COBA Water Treatment Plant
PWS ID No.: OK 1021508
Month: June
Year: 2025

Date	Distribution Total Chlorine mg/L A.M. Sample				Distribution Total Chlorine mg/L P.M. Sample			
	Time	Location	mg/L	Sampler	Time	Location	mg/L	Sampler
1	11:58	515 W. Quanah Pl.	3.30	J.B.	12:45	1116 W. Granger St.	3.00	J.B.
2	10:38	4121 E. Omaha St.	2.40	ML	12:13	1817 S. Willow Ave.	2.70	ML
3	9:32	609 E. Kingsport St.	2.70	AR	1:30	3301 W. Oakland St.	2.40	AR
4	8:48	3706 S. Orange Cir.	2.60	ML	12:33	1709 N. 21st St.	2.90	ML
5	7:38	2909 E Montpelier	3.40	ML	12:27	608 E Pensecola	3.10	ML
6	08:17	1627 E. Washington Pl.	3.20	M.L	12:29	4301 S. Aspen Pl.	3.20	M.L.
7	11:36	909 E. College St.	3.60	T.R.	12:28	2401 W. Omaha St.	3.20	T.R.
8	11:52	36500 E. 66th St. S.	3.70	R.M.	18:35	6057 S. 353rd E. Ave.	1.90	R.M.
9	10:51	1729 S. Pine Ave	2.70	ML	1:04	1116 W. Granger St	2.20	ML
10	8:52	4001 S. Chestnut Ave.	3.10	ML	12:19	7900 E. Norman St.	3.10	ML
11	8:37	2513 E. Dallas St.	2.60	ML	12:04	4608 W.Eagle Pass St.	3.20	ML
12	10:48	4604 W. Loisville St.	3.00	ML	12:50	221 N. 10th	3.10	ML
13	09:18	523 W. Detroit St.	2.90	M.L.	12:40	901 W. Albuquerque St.	2.90	M.L.
14	10:45	2700 N 7th St.	2.90	TR	17:02	1301 N 53rd St.	3.20	ME
15	08:50	702 E. Mason Dr.	3.10	J.B.	15:50	1903 W. Rockport Pl.	3.00	J.B.
16	11:02	2909 E. Montplier St.	3.00	ML	1:28	13725 S. 124th E. Ave.	2.70	ML
17	8:29	1116 W. Granger	3.50	ML	12:01	1817 S. Date Ave.	2.60	ML
18	10:05	4417 W. College Ct.	3.10	AR	2:04	1900 E Reno St.	3.70	AR
19	09:18	1817 S. Willow Ave.	2.70	M.L.	13:53	4121 E. Omaha St.	2.10	M.L.
20	08:22	601 E. Van Buren St.	3.50	M.L.	12:00	804 N. 1st St.	3.40	M.L.
21	11:00	1116 W. Granger St.	2.90	T.R.	12:10	2700 N. 7th St.	3.20	T.R.
22	10:38	2909 E. Montpelier St.	3.50	R.M.	16:00	1903 W. Rockport Pl.	2.80	R.M.
23	11:24	515 W. Quanah Pl.	3.20	JS	1:20	1005 N. Willow Ave.	3.40	JS
24	7:55	3706 S. Orange Circle	2.40	JS	12:28	4121 E Omaha	2.30	JS
25	10:30	1116 W. Granger St.	3.40	JS	3:00	3314 S. Ash Ave.	3.80	JS
26	9:18	228 W Waco St.	3.50	ML	1:24	604 N. Fir Ave.	3.40	ML
27	9:47	1911 S Nyssa Pl	2.40	ML	12:06	300 S 64th St	3.40	ML
28	11:38	1116 W. Granger St.	2.10	T.R.	12:22	2910 S. Ash Pl.	3.20	T.R.
29	11:35	1301 N. 53rd St.	3.70	J.B.	12:15	5005 S. Lions Ave.	3.50	J.B.
30	09:31	1413 N. 24th St.	3.50	M.L.	14:28	2737 S. Elder Ave.	3.30	M.L.
		Average	3.05			Average	3.00	
		Min.	2.10			Min.	1.90	
		Max.	3.70			Max.	3.80	