

BROKEN ARROW PLANNING COMMISSION AND CITY COUNCIL SUBDIVISION PLAT REVIEW CHECKLIST

PLAT INFORMATION

NAME OF PLAT: Whiskey Ridge
CASE NUMBER: PT16-114
RELATED CASE NUMBERS: PUD 256 and BAZ 1949
COUNTY: Wagoner
SECTION/TOWNSHIP/RANGE: 19/T19N/R15E
GENERAL LOCATION: Southeast corner of 23rd Street and Rockford Street
CURRENT ZONING: A-1
SANITARY SEWER BASIN: Green Country
STORM WATER DRAINAGE BASIN: Spunky Creek

ENGINEER: AAB Engineering, LLC
ENGINEER ADDRESS: P.O. Box 2136
Sand Springs, OK 74063
ENGINEER PHONE NUMBER: 918-514-4283

DEVELOPER: Wellington Investments, Inc.
DEVELOPER ADDRESS: 16310 E. 41st Street
Tulsa, OK 74134
DEVELOPER PHONE NUMBER: 918-451-8144

PRELIMINARY PLAT

APPLICATION MADE: December 5, 2016
TOTAL ACREAGE: 142.16
NUMBER OF LOTS: 442
TAC MEETING DATE: 01-10-2017
PLANNING COMMISSION MEETING DATE: 01-12-2017
COMMENTS:

1. _____ Place the total acreage on Sheet 1 with the Subdivision Statistics.
2. _____ Add addresses and street names as assigned by the City of Broken Arrow.
3. _____ Clarify the width of the Public Service ROW Easement along the east boundary. Is the total width of the Public Service ROW Easement 100 feet? If so, does it allow other utilities, such as a sanitary sewer line, to be located in it? If other utilities are allowed in this easement, provide a written statement (email is acceptable) stating such and show a utility easement of at least 17.5 feet in width along Rockford Street and a north/south utility easement near the east boundary. If other utilities are not allowed in this easement, provide a 17.5-foot wide utility easement adjacent to the Public Service ROW easement. Also, if the Public Service ROW Easement is 100 feet, what does the dashed line in the middle represent?
4. _____ Place case number (PT16-114) in lower right corner of plat.
5. _____ Provide a corner clip at the intersection of 23rd Street and Rockford Street. In addition, provide corner clips where streets intersect 23rd Street and Rockford Street.
6. _____ Add the following note to Sheet 1 and Sheet 2, "Restrictive Access – No vehicular access shall be allowed along lot lines with 15-foot building line setbacks. In the event that garage access is planned from the side yard, the minimum building setback along the side yard will be 20 feet. Only one garage access frontage is allowed on each lot."
7. _____ Label and add dimensions to the area to the west of Lot 69, Block 6 and Lot 1, Block 9.
8. _____ As per the Subdivision Regulations, the width of the right-of-way within 350 feet of the intersection of Rockford Street and 23rd Street needs to be at least 65 feet from the Section Line. After 350 feet, the right-of-way is to transition back at a 30-degree angle. In addition, within 350 feet of the arterial street intersection, the utility easement needs to be at least 22.5 feet in width transitioning back at a 30-degree angle to 17.5 feet. Either provide a 17.5-foot utility easement adjacent to all of 23rd Street, or show the reserve areas as utility easements.
9. _____ Show and label the width of the easement along the south boundary. If this is part of the Public Service ROW Easement, are other utilities allowed in the Public Service ROW easement along the south boundary? If so, provide a written statement (email is acceptable) stating such. In addition, show a 17.5-foot utility easement along the south boundary. If other utilities are not allowed, provide a 17.5-foot wide utility easement adjacent to the Public Service ROW easement.
10. _____ Label the FIRM panel map number associated with the 100-year floodplain.
11. _____ In the covenants, identify that the maintenance of the Reserve Areas is the responsibility of the property owner.

12. ____ Identify the width of the right-of-way of the street intersecting Rockford Street.
13. ____ PUD 256 states that the front building setback line is 20 feet. The plat shows a 25-foot front building setback line. Please modify either the PUD or the plat to reflect the same front building setback line.
14. ____ Please provide a written statement (email is acceptable) that all the pie shaped lots are at least 60 feet in width at the front building setback line.
15. ____ There are several type overs, which makes reading the underlying information difficult, especially when the plat is reduced. Please make revisions so that there are no type overs.
16. ____ Either show Reserves A, B, and D as utility easements, or show the utility easement to extend across the Reserves.
17. ____ Identify the width of the utility easement between Lots 19 and 20, Block 14.
18. ____ Provide dimensions for Reserve B.
19. ____ Provide bearings and dimensions for the perimeter boundaries of the plat.
20. ____ Label the building setback line along the east side of Lot 37, Block 4. If the building line setback is less than 20 feet, show restrictive access.
21. ____ The PUD language in Section II of the covenants shall coincide with PUD 256 as approved by the City Council.
22. ____ Please review Section I.C of the covenants. The City of Broken Arrow is not responsible for maintaining any of the water lines and sanitary sewer lines in this subdivision.
23. ____ Where are the Overland Detention and Easements referenced in Section I.G of the covenants?
24. ____ Revise Section I.H of the covenants. This property is not adjacent to Omaha Street.
25. ____ Section V.C of the covenants that references the PUD requirements of Section II is incorrect and needs to be modified to be in compliance with the Zoning Ordinance.
26. ____ Add bearings and dimensions that are missing.
27. ____ If this subdivision going to be constructed and platted in phases, there still needs to be only one overall Homeowners Association that will be responsible for the Reserve Areas and fencing along the arterial streets.
28. ____ Submit a detention determination to the Broken Arrow Stormwater Manager and refer to the assigned DD number on a detention note on the final plat.
29. ____ Revise the line type shown for the FEMA 100-year floodplain boundary. The line type used has a very large gap in it between the line and a dotted portion within the line. That large gap in the line type does not accurately show where the floodplain boundary is in areas where there are sharp bends in the floodplain boundary line. Revise to a more compact line type.
30. ____ The FEMA 100-year floodplain boundary of Spunky Creek appears to clip portions of Lots 52 and 53 of Block 6 and 25 and 26 of Block 10. It is recommended that those property boundaries be pulled back outside of the 100-year floodplain or else multiple City of Broken Arrow Floodplain Code requirements will affect platting and development on those residential lots. In addition, these lots will require identification on the plat and accompanying covenant language stating the following: No solid type fence, fill material, raised beds or any structure shall be placed within the designated FEMA 100-year floodplain.
31. ____ The Green Country Sewer District Treatment Plant has its plant discharge pipe discharging to Spunky Creek right at the headwall at the south side of the Rockford Street creek crossing near the northern end of proposed Reserve C. No easements are shown on this preliminary plat in that area or in the Rockford Street vicinity. Show all applicable Green Country Sewer District easements on this plat.
32. ____ The Conceptual Improvements Plan submitted with the Preliminary Plat shows proposed public storm sewers between side yards in 14 different locations on that plan, but none of those locations has a utility easement shown in the side yard of the preliminary plat. Coordinate with engineering plans and provide the required easement coverage of public storm sewers and other public utilities.
33. ____ Label the area east of Lots 1-13 of Block 17 as "Green Country LLC."
34. ____ Section I.G of the covenants lists details Overland Detention and Easements, but no easements of those type are identified on the face of the plat. Revise.
35. ____ Section I.G should be retitled to read," Overland Drainage and Detention Easements."
36. ____ Section I.I titled Reserve Areas will need more detail provided to cover specific uses and limitations of the reserve areas including floodplain and stormwater detention language.
37. ____ Section IV detailing Homeowners Association information states that they will be responsible maintenance of Reserve A. It is not stated who will be responsible for Reserves B, C, and D. Clarify and revise.

CONDITIONAL FINAL PLAT

NAME OF CONDITIONAL FINAL PLAT:

APPLICATION MADE:

TOTAL ACREAGE:

NUMBER OF LOTS:

TAC MEETING DATE:

PLANNING COMMISSION MEETING DATE:

CITY COUNCIL MEETING DATE:

COMMENTS:

- 38. _____
- 39. _____
- 40. _____
- 41. _____

CONDITIONS TO BE MET PRIOR TO FINAL RELEASE OF PLAT

LETTER OF APPROVAL FROM UTILITY COMPANY SUBMITTED?

- ____ NATURAL GAS COMPANY APPROVAL
- ____ ELECTRIC COMPANY APPROVAL
- ____ TELEPHONE COMPANY APPROVAL
- ____ CABLE COMPANY APPROVAL

CERTIFICATE OF RECORDS SEARCH FROM OKLAHOMA CORPORATION COMMISSION SUBMITTED?

- ____ OK CORPORATION COMMISSION CERTIFICATE OF RECORDS SEARCH
OKLAHOMA CORPORATION COMMISSION, CAROL COLLETT 405-521-2108

- ____ BUILDING PAD ELEVATIONS ON EACH LOT PLACED ON A COPY OF THE FINAL PLAT
- ____ MONUMENTS SHOWN ON PLAT
- ____ SLOPE ANALYSIS (1:4) FOR LOTS ADJACENT TO DRAINAGE CHANNELS APPROVED

DEVELOPMENT SERVICES/ENGINEERING APPROVAL

- ____ STORMWATER PLANS, APPROVED ON:
- ____ PAVING PLANS, APPROVED ON:
- ____ WATER PLANS, APPROVED ON:
- ____ SANITARY SEWER PLANS, APPROVED ON:
- ____ SEWAGE DISPOSAL PLANS, APPROVED BY DEPARTMENT OF ENVIRONMENTAL QUALITY ON:
- ____ WATER PLANS, APPROVED BY DEPARTMENT OF ENVIRONMENTAL QUALITY ON: _____
- ____ IS A SIDEWALK PERFORMANCE BOND DUE? _____ HAVE THEY BEEN SUBMITTED? _____
- ____ ARE PERFORMANCE BONDS OR ESCROW AGREEMENT DUE FOR WATER, STORM SEWERS, SANITARY SEWER AND PAVING? (CIRCLE APPLICABLE) _____ HAVE THEY BEEN SUBMITTED? _____
- ____ ENGINEERING DEPARTMENT/DEVELOPMENT SERVICES REVIEW COMPLETE ON: _____

PLANNING DEPARTMENT APPROVAL

- ____ ADDRESSES REVIEWED AND APPROVED
- ____ DETENTION DETERMINATION # ASSIGNED AND VERIFIED?
- ____ PLANNING DEPARTMENT REVIEW COMPLETE ON:
- ____ FINAL PLAT RECEIVED IN PLANNING DEPARTMENT AFTER UTILITY COMPANY SIGN OFF ON:
- ____ FINAL PLAT SENT TO ENGINEERING DEPARTMENT FOR FINAL REVIEW ON:

FEES

- ____ FINAL PLAT PROCESSING FEE \$ _____
- ____ WATER LINE (S) UNDER PAYBACK CONTRACT \$ _____
- ____ EXCESS SEWER CAPACITY FEE \$ _____
- ____ ACCELERATION/DECELERATION LANES ESCROW \$ _____
- ____ WATER LINE CONNECTIONS, PAYABLE TO CITY OR OTHERS \$ _____
- ____ SEWER LINE CONNECTIONS, PAYABLE TO CITY OR OTHERS \$ _____
- ____ STREET IMPROVEMENT (WIDENING) ASSESSMENTS \$ _____
- ____ DRAINAGE SYSTEM IMPROVEMENTS PRO RATA COST \$ _____
- ____ REIMBURSEMENT TO CITY OR OTHERS FOR WATER LINE CON. \$ _____
- ____ REIMBURSEMENT TO CITY OR OTHERS FOR SEWER LINE CON. \$ _____
- ____ STREET SIGNS, LIGHTS, ETC. \$ _____
- ____ STORM WATER FEE-IN-LIEU OF DETENTION \$ _____

TOTAL FEE(S)

\$_____

FINAL PROCESSING OF PLAT

____ DEVELOPMENT ENGINEER SUBMIT FINAL PLAT FOR MAYOR AND CITY CLERK SIGNATURE

____ FEES PAID ON: _____ IN THE AMOUNT OF: _____

____ DEVELOPMENT ENGINEER PICK UP FINAL PLAT FOR FILING

____ 11 COPIES OF FILED PLAT SUBMITTED TO PLANNING DEPARTMENT

____ PDF OF RECORDED PLAT SUBMITTED TO PLANNING DEPARTMENT