



REMARKS : No data on the weather station for this day
Influent flowmeter was down used the effluent flowmeter number for the Influent flow
Operator run test but no issue with the pump and CL2 analyzer didn't pick it up. Not sure if we were out or just an error in the lab

Electrical Costs :	22,489.35
Labor Costs :	53,717.88
Chemicals, Lab Supplies & Services :	9,373.25
Repairs, Maint., Services & Admin. :	25,666.08
Sludge (Generation & Transportation) :	20,125.09
TOTAL COSTS :	131,371.65
COST / TRTD. 1000 GAL :	1.48

I hereby certify the above to be correct to the best
of my knowledge.

Signed:  _____

Title: LLWRRF Manager