



REMARKS :	Plant was offline due to switching from West Oxidation Ditch to the East Oxd. Ditch. Wasting (WAS) was shut down at 5am. RAS Pump No. 1 offline causing lower RAS flow
-----------	---

Electrical Costs :	20,782.01
Labor Costs :	21,055.91
Chemicals, Lab Supplies & Services :	9,670.64
Repairs, Maint., Services & Admin. :	9,763.19
Sludge (Generation & Transportation) :	21,011.55
TOTAL COSTS :	82,283.30
COST / TRTD. 1000 GAL :	0.82

I hereby certify the above to be correct to the best of my knowledge.

Signed: 

Title: LLWWTP Manager