

Request for Action

File #: 19-1011, Version: 1

| Broken Arrow Planning Commission | | | | |
|----------------------------------|--|--|--|--|
| | 09-12-2019 | | | |
| To: From: Title: | Chairman and Commission Members Development Services Department | | | |
| | Public hearing, consideration, and possible action regarding PUD-292 (Planned Unit Development) and BAZ-2034 (Rezoning), Casey's General Store, 1.77 acres, A-1 to PUD-292/CG, located on the southeast corner of Kenosha Street (71 st Street) and 37 th Street (209 th E. Avenue) | | | |
| Background: | | | | |
| Applicant: | Marni Beck, Casey's Marketing Company | | | |
| Owner: | Armory LLC | | | |
| Developer: | Casey's General Store | | | |
| Engineer: | Morrison Shipley Engineers, Inc. | | | |
| Location: | Southeast corner of Kenosha Street (71st Street) and 37th Street (209th E. Avenue) | | | |
| Size of Tract | 1.77 acres | | | |
| Present Zoning: | A-1 | | | |
| Proposed Zoning: | PUD-292/CG | | | |
| Comp Plan: | Level 6 | | | |

Planned Unit Development (PUD)-292 involves a 1.77 acre parcel located on the southeast corner of Kenosha Street (71st Street) and 37th Street (209 E. Avenue). In conjunction with PUD-292, applicant has submitted BAZ-2034, a request to change the underlying zoning from A-1 (Agricultural District) to CG (Commercial General). A preliminary plat has also been submitted in conjunction with this rezoning request.

Casey's General Store is proposing to construct a convenience store on the property. One point of access is proposed to Kenosha Street and one point of access is proposed to 37th Street. The access points, which will be shared with the adjacent property to the east and to the south, meet the spacing requirements of the Zoning Ordinance.

Casey's General Store is proposed to be developed in accordance with the City of Broken Arrow Zoning Ordinance and the use and development regulations of the CG district, except as summarized below.

SUMMARY OF DEVIATION FROM THE BROKEN ARROW ZONING ORDINANCE

| Item | Broken Arrow Zoning Ordinance | PUD-292 Request |
|--|---|---|
| Minimum Front Building Setback (Kenosha Street and 37 th Street) | 50 feet | 40 feet |
| | From an abutting residential or A-1 district: 50 feet | 20 feet |
| Masonry Materials | street are to consist of masonry, concrete panels, glass block, glass curtain walls, EIFS, or stucco. There are no requirements on sides not facing a street. | All four sides of the building will consist of masonry materials. In addition, canopy columns will be wrapped in brick. The dumpster will have brick walls along with wood gates. The HVAC units will be screened with a metal parapet that matches the color of the proposed building façade materials. |
| | zoning. | •••• |

| Freestanding Signs | Up to 30 feet in height and up to | One proposed freestanding sign. |
|--------------------|---|-------------------------------------|
| | 500 square feet with multiple users | Sign is limited to 15 feet in |
| | and 300 square feet for a single | height, 120 square feet in size, |
| | user. However, no signs shall be | and will have a brick base. |
| | located within 50 feet of any | |
| | residentially zoned district. Any | |
| | sign located within 50 feet to 100 | |
| | feet of a residentially zoned district | |
| | shall be limited to 8 feet in height | |
| | and 64 square feet. No flashing, | |
| | twinkling, or animated sign shall be | |
| | located within 20 feet of the right of | |
| | way line or within 200 feet of a | |
| | designated residential district. Any | |
| | sign within 200 feet of a residential | |
| | district is limited to 300 square feet. | |
| Sidewalks | 5 feet in width, located one foot | Because of gas marker signs, |
| | from the property line in the street | power poles, a telephone |
| | right-of-way. | substation, and other potential |
| | | obstacles, a 5-foot wide sidewalk |
| | | will be located on the property |
| | | and not in the street right-of-way. |
| | | As part of the platting process, a |
| | | sidewalk easement will be |
| | | provided. |
| Parking | One space per dispensing station | One space per dispensing station |
| | plus one space per 200 square feet | will be provided along with 22 |
| | of retail space. For 5,382 square | parking spaces. Some of the |
| | feet of retail space, 27 parking | parking will be located in front of |
| | spaces would be required. | the dumpster enclosure. |
| L | | |

SURROUNDING LAND USES/ZONING/COMPREHENSIVE PLAN

The surrounding properties contain the following uses, along with the following development guide and zoning designations:

| | Development Guide (2019) | Zoning | Land Use |
|-------|-----------------------------|--------|------------------------------------|
| North | | | Retail commercial and undeveloped. |

| East | Level 6 | A-1 | Undeveloped |
|-------|---------|-----|-------------|
| South | Level 6 | A-1 | Undeveloped |
| West | Level 6 | A-1 | Undeveloped |

The property associated with PUD-292and BAZ-2034 is designated as Level 6 in the Comprehensive Plan recently adopted by the City Council. CG (Commercial General) zoning is considered to be in conformance with the Comprehensive Plan in Level 6.

According to Section 6.4 of the Zoning Ordinance, the PUD provisions are established for one (1) or more of the following purposes:

- 1. To permit and encourage innovative land development while maintaining appropriate limitation on the character and intensity of use and assuring compatibility with adjoining and proximate properties.
- 2. To permit greater flexibility within the development to best utilize the physical features of the particular site in exchange for greater public benefits than would otherwise be achieved through development under this Ordinance.
- 3. To encourage the provision and preservation of meaningful open space.
- 4. To encourage integrated and unified design and function of the various uses comprising the planned unit development.
- 5. To encourage a more productive use of land consistent with the public objectives and standards of accessibility, safety, infra structure and land use compatibility.

In Staff's opinion, PUD-292 satisfies items 1, 2, 4 and 5 of Section 6.4.A of the Zoning Ordinance. (1) Applicant has designed the site so that points of access are shared with abutting development thereby helping to assure compatibility with adjoining and proximate properties. The one proposed freestanding sign is limited to 15 feet in height and 120 square feet in size, which makes it compatible with the development on the north side of Kenosha Street. Applicant is requesting a slight reduction in parking spaces, but is satisfied that the amount of parking provided will meet their needs. Masonry building materials will be used around the entire perimeter of the building and on the canopy support poles, thereby creating a better appearance from the Creek Turnpike and adjacent properties. (2) Building setbacks along the street frontage to the north and west are reduced by 10 feet and along the east and south boundaries are reduced by 30 feet. In the future, the property to the east and south will more than likely be used by nonresidential uses. Reducing the building line setback allows better utilization of the site and greater flexibility. In addition, since no adjoining residential uses are foreseen in the future, an opaque screening fence will not be needed. (4) Points of access to Kenosha Street and 37th Street are shared with the adjacent properties creating a unified design with future development. (5) The public sidewalk will be located on private property, thereby avoiding obstacles in the public right-of-way and making safer pedestrian travel.

According to FEMA maps, none of the property is located in a 100-year floodplain area. Stormwater detention will occur onsite in an underground facility. Sanitary sewer service will be provided by the City of Broken Arrow, while water will be provided by Rural Water District #4.

Attachments: Case map Aerial photo Comprehensive Plan Future Development Guide PUD-292 design statement

Recommendation:

Based upon the Comprehensive Plan, the PUD submitted with BAZ-2034, the location of the property, and the surrounding land uses, Staff recommends that PUD-292 and BAZ-2034 be approved, subject to the property being platted.

Reviewed and approved by: Larry R. Curtis

BDM