

**National Pollutant Discharge Elimination System (NPDES)
Oklahoma Department of Environmental Quality Discharge Monitoring Report (DMR)**

PERMITTEE NAME: Broken Arrow, City of
MAILING: NESESES11T17NR14EIM
ADDRESS: Broken Arrow, OK 74013
FACILITY: Broken Arrow WWT
LOCATION: NESESES11T17NR14EIM
Broken Arrow, OK 74013

PERMIT NUMBER: OK0040053

MONITORING: 001A

POINT:

COUNTY:

Tulsa

Monitoring Period: 2020-02-01 To: 2020-02-29

NO DISCHARGE FROM SITE:

()

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
		Average	Maximum		Minimum	Average	Maximum				
BOD, 5-DAY (20 DEG. C)	Sample Measurement	618.68	*****	26 lbs/day	*****	11.10	16.20	19 mg/l	0	Five Per Week	COMP12
PARAM CODE: 00310 Stage Code: 1 Effluent Gross	Permit Requirement	2001.6 Monthly Average	*****		*****	30 Monthly Average	45 Weekly Average			Five Per Week	COMP12
PH	Sample Measurement	*****	*****		7.1	*****	7.3	12 S.U.	0	Daily	GRAB
PARAM CODE: 00400 Stage Code: 1 Effluent Gross	Permit Requirement	*****	*****		6.5 Minimum	*****	9.0 Maximum			Daily	GRAB
SOLIDS, TOTAL SUSPENDED	Sample Measurement	289.45	*****	26 lbs/day	*****	5.20	10.20	19 mg/l	0	Five Per Week	COMP12
PARAM CODE: 00530 Stage Code: 1 Effluent Gross	Permit Requirement	2001.6 Monthly Average	*****		*****	30 Monthly Average	45 Weekly Average			Five Per Week	COMP12
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	Sample Measurement	6.577	8.976	03 MGD	*****	*****	*****		0	Daily	TOTALZ
PARAM CODE: 50050 Stage Code: 1 Effluent Gross	Permit Requirement	Report Monthly Average	Report Maximum Daily		*****	*****	*****			Daily	TOTALZ
CHLORINE, TOTAL RESIDUAL	Sample Measurement	*****	*****		*****	*****	1.26	19 mg/l	1	Daily	GRAB
PARAM CODE: 50060 Stage Code: A Disinfection, Process Complete	Permit Requirement	*****	*****		*****	*****	0.099 Instantaneous Maximum			Daily	GRAB
E.COLI	Sample Measurement	*****	*****		*****	6.5	66.0	30 MPN/100mL	0	Weekly	GRAB
PARAM CODE: 51040 Stage Code: 1 Effluent Gross	Permit Requirement	*****	*****		*****	630 Geometric Mean	2030 Maximum Daily			Weekly	GRAB
SOLIDS, TOTAL DISSOLVED-180 DEG.C	Sample Measurement	28712	*****	26 lbs/day	*****	537	537	19 mg/l	0	Monthly	COMP12
PARAM CODE: 70300 Stage Code: 1 Effluent Gross	Permit Requirement	77929 Monthly Average	*****		*****	1168 Monthly Average	1168 Maximum Daily			Monthly	COMP12

Name/Title of Principal Executive Officer Or Authorized Agent WWTP Mgr.	I CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHMENTS WERE PREPARED UNDER MY DIRECTION OR SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY GATHER AND EVALUATE THE INFORMATION SUBMITTED. BASED ON MY INQUIRY OF THE PERSON OR PERSONS WHO MANAGE THE SYSTEM, OR THOSE PERSONS DIRECTLY RESPONSIBLE FOR GATHERING THE INFORMATION, THE INFORMATION SUBMITTED IS, TO THE BEST OF MY KNOWLEDGE AND BELIEF, TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.	Signature of Principal Executive Officer Or Authorized Agent	Telephone No
		David Handy	918-455-4762

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

**National Pollutant Discharge Elimination System (NPDES)
Oklahoma Department of Environmental Quality Discharge Monitoring Report (DMR)**

PERMITTEE NAME: Broken Arrow, City of
MAILING: NESESES11T17NR14EIM
ADDRESS: Broken Arrow, OK 74013
FACILITY: Broken Arrow WWT
LOCATION: NESESES11T17NR14EIM
 Broken Arrow, OK 74013

PERMIT NUMBER: OK0040053

MONITORING 001A

COUNTY:

Tulsa

POINT:

Monitoring 2020-02-01 To: 2020-02-29
Period :

NO DISCHARGE FROM SITE: ()

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
		Average	Maximum		Minimum	Average	Maximum				
MERCURY, TOTAL (AS HG)	Sample Measurement	0.0027	*****	26 lbs/day	*****	< 0.05	< 0.05	28 ug/l	0	Monthly	COMP12
PARAM CODE: 71900 Stage Code: 1 Effluent Gross	Permit Requirement	0.0635 Monthly Average	*****		*****	0.952 Monthly Average	1.9 Maximum Daily			Monthly	COMP12
Name/Title of Principal Executive Officer Or Authorized Agent		I CERTIFY UNDER PENALTY OF LAW THAT THIS DOCUMENT AND ALL ATTACHMENTS WERE PREPARED UNDER MY DIRECTION OR SUPERVISION IN ACCORDANCE WITH A SYSTEM DESIGNED TO ASSURE THAT QUALIFIED PERSONNEL PROPERLY GATHER AND EVALUATE THE INFORMATION SUBMITTED. BASED ON MY INQUIRY OF THE PERSON OR PERSONS WHO MANAGE THE SYSTEM, OR THOSE PERSONS DIRECTLY RESPONSIBLE FOR GATHERING THE INFORMATION, THE INFORMATION SUBMITTED IS, TO THE BEST OF MY KNOWLEDGE AND BELIEF, TRUE, ACCURATE, AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT FOR KNOWING VIOLATIONS.							Signature of Principal Executive Officer Or Authorized Agent		Telephone No
WWTP Mgr.								David Handy		918-455-4762	

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Page 2

GENERAL REPORT COMMENT:

On February 24, 2020 at approximately 7:30am, a drawdown was performed on Sodium Bisulfite Pump No.1. The result was 110ml/min. The CL17 Analyzer reading was 0.03mg/L. At 8:54am the daily scheduled Total Residual Chlorine (TRC) test was performed with a result of 1.26 mg/L. Facility Manager David Handy was advised of the result. Mr. Handy and a operator returned to the sodium bisulfite room and performed a drawdown on Pump No. 1 again. The result was 112ml/min. The CL17 Analyzer reading was 0.67 mg/L. A decision was made to switch to pump No. 2 and a drawdown was performed. The result was 119 ml/min. At 9:30am a TRC was performed again with a result of <0.05 mg/L. There was no alarm callout due to a scaling issue with the CL17 Analyzer and the alarm setpoints on the new recently installed SCADA system. The contractor has been notified of the scaling issue and has it scheduled for repair. The alarm callout setpoints have been adjusted for the issue and operators have stepped up monitoring.