

multi-family dwellings and other structures permitted to be of Type III construction (construction in which the exterior walls are of noncombustible materials and the interior building elements are of any material permitted by the International Building Code), Type IV construction (construction in which the exterior walls are of noncombustible materials and the interior building elements are of solid or laminated wood without concealed spaces), and Type V construction (construction in which the structural elements, exterior walls and interior walls are of any materials permitted by the International Building Code, typically light-frame wood construction). However the City amendment has not been updated to coincide with the NEC.

The proposed amendment to the 2014 NEC section 334.10 would allow Nonmetallic-Sheathed Cable to be installed in One- and two-family dwellings, their attached or detached garages, and their storage buildings and in Multi-family dwellings permitted to be of Types III, IV, and V construction without the height restriction of three floors and remove the allowance of Nonmetallic-Sheathed Cable in other structures of Types III, IV, and V.

The proposed amendment to the 2014 NEC section 334.12 will continue to prohibit Nonmetallic-Sheathed Cable in hotels, motels, commercial structures, office buildings, industrial buildings or similar uses.

These amendments will not reduce the health, safety and welfare of the City and its citizens.

Cost: No Cost

Funding Source: No Source

Requested By: Larry Curtis, Director of Community Development

Approved By: City Manager's Office

Attachments: Preview Ordinance No. 3629
2014 NEC Sections 334.10 and 334.12 as published in the NEC
2014 NEC Sections 334.10 and 334.12 showing the proposed amendments
HBA Letter of Support

Recommendation:

Preview the Ordinance and set for adoption.