

Pretreatment staff mailed 113 letters to residents upstream of grease-related sanitary sewer overflows. The letters inform residents of the grease and other obstructions that sewer collection system crews are finding in sewer lines that cause the overflows. The letters also give residents suggestions on how they can partner with the City to prevent pollution caused by sewer overflows and directs them to install a backflow preventer for protection from sewer backups.

Broken Arrow Dental Facilities were mailed “One-time compliance reports” that are due to the City by July 14, 2020. The City of Broken Arrow is required by the Environmental Protection Agency (EPA) to collect the compliance reports and ensure compliance with 40 CFR 441. All existing facilities subject to the regulations must install an amalgam separator, implement best management practices for maintaining the separators, and certify such to the City of Broken Arrow by July 14, 2020. Any new dental facility must comply immediately.

This concludes the summary. Staff recommends that the Authority acknowledge the November 2018 to January 2019 Pretreatment Report to RMUA.

Cost: \$0

Funding Source: Operational Funds

Requested By: Charles Vokes, Utilities Director

Approved By: Michael L. Spurgeon, City Manager

Attachments: November 2018 to January 2019 Pretreatment Program Report to RMUA

Recommendation:

Acknowledge submittal of November 2018 to January 2019 Pretreatment Report to the Regional Metropolitan Utility Authority