



City of Broken Arrow

Legislation Details (With Text)

File #: 18-879 **Name:**
Type: Consent Item **Status:** Passed
File created: 7/20/2018 **In control:** Broken Arrow Municipal Authority
On agenda: 8/7/2018 **Final action:** 8/7/2018
Title: Acknowledgement of submittal of the Broken Arrow Municipal Authority's Wastewater Discharge Monitoring Report for the month of June 2018

Sponsors:

Indexes:

Code sections:

Attachments: 1. June Discharge Monitoring Report, 2. June Monthly Operational Report

Date	Ver.	Action By	Action	Result
8/7/2018	1	Broken Arrow Municipal Authority	approved	Pass

**Broken Arrow Municipal Authority
Meeting of: 08-07-2018**

Title: Acknowledgement of submittal of the Broken Arrow Municipal Authority's Wastewater Discharge Monitoring Report for the month of June 2018

Background:

In an effort to provide the Authority and the Public more information with respect to our community's wastewater collection and treatment at the city's Lynn Lane Wastewater Treatment Plant, the Utilities Department staff is attaching a copy of the June 2018 Oklahoma Department of Environmental Quality (ODEQ) Discharge Monitoring Report (DMR) submitted to ODEQ on July 13, 2018.

Over the course of the month of June 2018, the total wastewater collected, treated and discharged is 84.75 million gallons (MG). The average flow was 2.825 MG.

This report will be updated on a monthly basis. Staff recommends the Authority acknowledge submittal of the Report.

Cost: None
Funding Source: None
Requested By: Ron Sullivan, Interim Utilities Director
Approved By: Michael L. Spurgeon, City Manager

Attachments: June Discharge Monitoring Report
 June Monthly Operational Report

Recommendation:

Acknowledgement of submittal of the Monthly Discharge Monitoring Report.