



City of Broken Arrow

Legislation Details (With Text)

File #: 16-1252 **Name:**
Type: Consent Item **Status:** Passed
File created: 10/10/2016 **In control:** Broken Arrow Municipal Authority
On agenda: 10/18/2016 **Final action:** 10/18/2016
Title: Acknowledgement of submittal of the Broken Arrow Municipal Authority's Water Supply Report for the month of September 2016

Sponsors:

Indexes:

Code sections:

Attachments: 1. September water usage report

Date	Ver.	Action By	Action	Result
10/18/2016	1	Broken Arrow Municipal Authority	approved	Pass

**Broken Arrow Municipal Authority
Meeting of: 10-18-2016**

To: Chairman and Authority Members
From: Department of Utilities
Title:

Acknowledgement of submittal of the Broken Arrow Municipal Authority's Water Supply Report for the month of September 2016

Background:

In an effort to provide the Authority and the Public more information with respect to our community's water usage, the Utilities Department Staff has prepared a Total Water Supply Report that records total daily water usage, as well as monthly water volume delivered to the community.

Over the course of the first nine (9) months of the year, the Maximum Water Plant Production Day was 20.5 million gallons per day (MGD) recorded on June 22, 2016. The Average Day usage through the end of September is 14.7 MGD. Total water treated at the plant up to the end of September is 3,344.7 million gallons (MG). Total water purchased from Tulsa is 90.6 MG.

The new 61st Tulsa connection was turned on August 4, 2016, and this additional supply supplements the 41st Street connection. Water Treatment Plant staff turn on/off both Tulsa connections to meet system demand.

This report will be updated on a monthly basis.

Cost: None
Prepared By: Anthony C. Daniel, Director of Utilities
Reviewed By: Utilities Department

**Assistant City Manager-Operations
Legal Department**

Approved By: Michael L. Spurgeon, City Manager

Attachments: Monthly Report

Recommendation:

No action needed