



City of Broken Arrow

Legislation Details (With Text)

File #:	17-2850	Name:	
Type:	Consent Item	Status:	Passed
File created:	10/31/2017	In control:	Broken Arrow Municipal Authority
On agenda:	11/7/2017	Final action:	11/7/2017
Title:	Acceptance of and authorization to execute a Tulsa County Board of County Commissioners Utility Permit for a Sanitary Sewer Installation by boring across Garnett Road for the Cottages at Cedar Ridge located one-quarter mile north of New Orleans Street, west of Garnett Road (Section 19, T18N, R14E)		

Sponsors:

Indexes:

Code sections:

Attachments: 1. Utility Permit-Tulsa County.pdf, 2. NET-Offsite Sanitary Sewer-Cottages at Cedar Ridge.pdf

Date	Ver.	Action By	Action	Result
11/7/2017	1	Broken Arrow Municipal Authority	approved	Pass

Broken Arrow Municipal Authority Meeting of: 11-07-2017

To: Chairman and Authority Members
From: Development Services Department
Title:

Acceptance of and authorization to execute a Tulsa County Board of County Commissioners Utility Permit for a Sanitary Sewer Installation by boring across Garnett Road for the Cottages at Cedar Ridge located one-quarter mile north of New Orleans Street, west of Garnett Road (Section 19, T18N, R14E)

Background:

Mike Case, President of Case and Associates, purchased a portion of the former Grace Fellowship property located one-quarter mile north of New Orleans Street and west of Garnett Road to develop a upscale apartment community called Cottages at Cedar Ridge

The property slopes eastward toward Garnett Road. The best route for sanitary sewer is eastward across Garnett and tie into the existing 48-inch Haikey Creek sanitary sewer trunk line. The sanitary sewer system involves 5 entities, City of Tulsa, Tulsa County, City of Broken Arrow, Oklahoma Turnpike Authority and Corps of Engineers.

Case and Associates has met with each entity and in some cases, multiple entities at the same time. They have received approvals so far from the entities including Broken Arrow. The sanitary sewer runs eastward across Garnett Road and the northern edge of the wetlands located in the City of Broken Arrow on Turnpike Authority property.

The attached utility permit requires signature for the City of Broken Arrow for the eastern half of the crossing of Garnett Road. Plans for the portion of the system in Broken Arrow are attached for reference. The sanitary

system is a 15-inch line capable of carrying the flows for the apartment project and future development north of the site.

Staff has reviewed the documents and recommends acceptance of the utility permit for signature.

Cost: **None**

Prepared By: **Michael Skates, P.E., CFM,**

Reviewed By: **Department of Engineering and Construction**
 Utilities Department
 Assistant City Manager - Operations
 Legal Department

Approved By: **Michael L. Spurgeon, City Manager**

Attachments: **Utility Permit-Tulsa County**
 NET-Offsite Sanitary Sewer-Cottages at Cedar Creek

Recommendation: **Accept the utility permit and authorize its execution.**