



# City of Broken Arrow

## Legislation Details (With Text)

---

**File #:** 21-504      **Name:**

**Type:** Consent Item      **Status:** Agenda Ready

**File created:** 4/13/2021      **In control:** Broken Arrow Municipal Authority

**On agenda:** 4/20/2021      **Final action:**

**Title:** Acknowledgement of the notification of the closing of the Consent Order issued by Oklahoma Department of Environmental Quality for the unpermitted discharges from the collection system

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. ODEQ Letter

Date	Ver.	Action By	Action	Result
------	------	-----------	--------	--------

### Broken Arrow Municipal Authority Meeting of: 04-20-2021

**Title:**

Acknowledgement of the notification of the closing of the Consent Order issued by Oklahoma Department of Environmental Quality for the unpermitted discharges from the collection system

**Background:**

On March 6, 2018, the Oklahoma Department of Environmental Quality issued a Consent Order to the City of Broken Arrow to address unpermitted discharges from the County Line Trunk Sewer. The discharges were due to a lack of capacity in the trunk sewer due to the line size and corrosion failures. Substantial completion of the rehabilitation of the County Line Trunk Sewer was achieved on October 2, 2020. On March 30, 2021, ODEQ sent a letter stating the Consent Order has been closed.

Total cost of compliance with the order was \$16,419,885.

**Cost:** N/A

**Funding Source:** N/A

**Requested By:** Charles Vokes, Utilities Director

**Approved By:** City Manager's Office

**Attachments:** ODEQ Letter

**Recommendation:**

**Acknowledge the notification of the closing of the Consent Order issued by Oklahoma Department of Environmental Quality for the unpermitted discharges from the collection system.**