



# City of Broken Arrow

## Request for Action

---

**File #:** 17-2125, **Version:** 1

---

**Broken Arrow Municipal Authority**  
**Meeting of: 05-02-17**

**To:** Chairman and Authority Members  
**From:** Engineering and Construction Department  
**Title:** Acknowledgement of receipt of Oklahoma Department of Environmental Quality (ODEQ) Permit No. SL000072170207 for rehabilitation of two digesters at the Lynn Lane Wastewater Treatment Plant (Project No. 165428)

**Background:**

The Oklahoma Department of Environmental Quality (ODEQ) issued the attached Permit No. SL000072170207 for rehabilitation of two (2) digesters by installing floating decanters, mechanical mixers, temperature probes, replacement of fine bubble disc membrane with stainless steel coarse bubble diffusers and all appurtenances at the Lynn Lane Wastewater Treatment Plant. ODEQ requested that the receipt of the permit be noted in the minutes of the next regular meeting of BAMA.

**Cost:** \$0.00  
**Prepared By:** Alex Mills, P.E., Engineering and Construction Director  
**Reviewed By:** Utilities Department  
Legal Department  
Assistant City Manager - Operations

**Approved By:** Michael L. Spurgeon, City Manager

**Attachments:** ODEQ Construction Permit No. SL000072170207

**Recommendation:** Acknowledge receipt of ODEQ Construction Permit No. SL000072170207 for rehabilitation of two digesters at the Lynn Lane Wastewater Treatment Plant